



केन्द्रीय प्रदूषण नियंत्रण बोर्ड
CENTRAL POLLUTION CONTROL BOARD
पर्यावरण, वन एवं जलवायु परिवर्तन मंत्रालय भारत सरकार
MINISTRY OF ENVIRONMENT, FOREST & CLIMATE CHANGE GOVT. OF INDIA

Speed Post

IPC-VII/ CETP/Vatva /2017 23550

February 23, 2017

To

The Member Secretary
Gujarat Pollution Control Board
Paryavaran Bhawan, Sector -10 A
Gandhinagar-382010 (Gujarat)

Sub: Directions under Section-5 of the Environment (Protection) Act, 1986 to CETP Vatva--reg.

Sir,

Directions under Section-5 of the Environment (Protection) Act, 1986 was issued to CETP Vatva (M/s The Green Environment Services Co-op Society Ltd.) vide CPCB letter dated 9/12/2016 (**Annexure-I**) for improving performance/compliance of CETP by improving compliance of inlet norms and proper operation & maintenance of CETP.

CETP Vatva vide letter dated 26.12.2016 replied to CPCB directions, under intimation to GPCB. In their letter, no clear reply has been given about compliance of CETP design inlet norms for all design parameters by member units and also about engaging of expert for operation and maintenance of CETP. Instead, it has been proposed to discharge effluent not meeting COD norms from the CETP and further to attain the outlet norms by dilution with treated sewage before disposal to river Sabarmati, which is not acceptable. In this regard, CPCB has already communicated to CETP Vatva vide letter dated 31/1/2017, a copy of which is enclosed for your ready reference (**Annexure-II**).

In view of above, GPCB is requested to follow-up with CETP Vatva and to ensure compliance of the directions issued by CPCB vide letter dated 9/12/2016 for improving the compliance of design inlet norms by member units and engaging expert for operation & maintenance of CETP. GPCB is further requested to submit the reports to CPCB on actions taken, in this regard, at an early date.

Yours faithfully

(Ajay Aggarwal)

AD & Incharge-IPC-VII

Encl: as above

Copy to:

AD & Regional Director (West)
Central Pollution Control Board
Parivesh Bhawan, Opp. VMC ward Office No. 10
Subhanpura,
Vadodara-390023

-: with the request to follow-up and to submit
the progress report

केन्द्रीय प्रदूषण नियंत्रण बोर्ड
निर्गत
दिनांक 23-2-17

g/c

'परिवेश भवन' पूर्वी अर्जुन नगर, दिल्ली-110032
Parivesh Bhawan, East Arjun Nagar, Delhi-110032

दूरभाष/Tel : 43102030, 22305792, वेबसाइट/Website : www.cpcb.nic.in