

Status of Sewage Treatment Plants in Uttarakhand (as on June 30,2022)

- Commissioned STPs - 53 (18 towns) with designed capacity – 341.2 MLD
- Operational STPs – 51* (Operational capacity -341.1 MLD) with Utilized capacity – 229.1 MLD (~67% of operational capacity)
- Compliance Status of operational STPs

	Compliance w.r.t. Hon'ble NGT vide order 30.04.2019	Compliance Status w.r.t MoEF norms dated 13.10.2017
Complying	7	9
Non-complying	44	42

- Non-operational STPs – 2 (Designed capacity – 0.1 MLD)
- STPs complying for Faecal Coliform norms (<230 MPN/100ml) – 8
- STPs non-complying for Faecal Coliform norms (>230 MPN/100ml) – 43

Operational and Compliance status of Sewage Treatment Plants in Uttarakhand

S. No.	Name of STPs/CETPs	Ganga Front Town	Treatment Technology	Designed Capacity (MLD)	Date of Inspection	Operational /Non-Operational Status	Compliance Status w.r.t Hon'ble NGT norms dated 30.04.2019	Compliance Status w.r.t MoEF&CC norms dated 13.10.2017
1	Gangotri	Gangotri	SBR	1	04.06.2022	Operational	Non-complying COD, BOD	Complying
2	Badrinath 1.0 MLD STP	Badrinath	SBR	1	08.06.2022	Operational	Non-complying FC	Non-complying FC
3	Badrinath 0.01MLD STP	Badrinath	MBBR	0.01	08.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying TSS, BOD, FC
4	Badrinath 0.26 MLD STP	Badrinath	SBR	0.26	08.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying TSS, BOD, FC
5	Old Suspension bridge	Chamoli-Gopeshwar	Electro coagulation	0.05	24.05.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying BOD, FC
6	Chamoli Ghat	Chamoli-Gopeshwar	Electro coagulation	0.76	24.05.2022	Operational	Non-complying TSS, FC	Non-complying FC
7	Vivekanand Colony STP (Leesa Bend)	Chamoli-Gopeshwar	Electro coagulation	1.19	10.06.2022	Operational	Non-complying FC	Non-complying FC
8	Pokhri Bend STP	Chamoli-Gopeshwar	Electro coagulation	1.25	11.06.2022	Operational	Non-complying BOD, FC	Non-complying FC
9	Deen Dayal Uppadyay Park	Chamoli-Gopeshwar	Electro coagulation	1.12	10.06.2022	Operational	Non-complying FC	Complying
10	Pokhri, Joshimath 1.08 MLD	Joshimath	SBR	1.08	09.06.2022	Operational	Complying	Complying

S. No.	Name of STPs/CETPs	Ganga Front Town	Treatment Technology	Designed Capacity (MLD)	Date of Inspection	Operational /Non-Operational Status	Compliance Status w.r.t Hon'ble NGT norms dated 30.04.2019	Compliance Status w.r.t MoEF&CC norms dated 13.10.2017
11	Forest Nala STP	Nandprayag	Electro coagulation	0.10	24.05.2022	Operational	Non-complying TSS, FC	Non-complying FC
12	Sangam Nala STP	Nandprayag	Electro coagulation	0.05	24.05.2022	Operational	Non-complying BOD, COD, TSS, Fc	Non-complying FC
13	Near Police Chowki STP 01	Karanprayag	Electro coagulation	0.05	24.5.2022	Operational	Non-complying FC	Non-complying FC
14	Old Bridge STP 02	Karanprayag	Electro coagulation	0.1	25.5.2022	Operational	Non-complying BOD, COD, TSS & FC	Non-complying BOD, FC
15	Near Ward 1 & 3 STP 05	Karanprayag	Electro coagulation	0.1	25.5.2022	Operational	Non-complying TSS, FC	Non-complying FC
16	BRO Bridge STP 04	Karanprayag	Electro coagulation	0.05	25.5.2022	Operational	Non-complying TSS, FC	Non-complying FC
17	Subhash Nagar STP 03	Karanprayag	Electro coagulation	0.05	24.5.2022	Operational	Non-complying FC	Non-complying FC
18	Near SBI Bank STP	Rudraprayag	Electro coagulation	0.1	24.06.2022	Operational	Non-complying BOD, COD, TSS & FC	Non-complying FC
19	Near Dart Pull STP	Rudraprayag	Electro coagulation	0.075	24.06.2022	Operational	Non-complying FC	Non-complying FC
20	Army Bend (Rudra Complex) STP 02	Rudraprayag	Electro coagulation	0.1	24.06.2022	Operational	Non-complying TSS, FC	Non-complying FC
21	Anoop Negi Memorial School STP	Rudraprayag	Electro coagulation	0.075	24.06.2022	Non-operational	-	-
22	Near Steel Bridge	Rudraprayag	Electro coagulation	0.125	24.06.2022	Operational	Non-complying FC	Non-complying FC
23	Baleni Road	Rudraprayag	Electro coagulation	0.05	24.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying FC
24	Gyansu	Uttarkashi	MBBR	2	03.06.2022	Operational	Complying	complying
25	Tekla STP	Uttarkashi	-	0.03	03.06.2022	Non-operational	-	
26	Tehri	Tehri	ASP	5	25.05.2022	Operational	Non-complying COD, TSS, FC	Non-complying FC
27	0.075 MLD STP Srikot	Srikot	FAB	0.075	23.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying FC

S. No.	Name of STPs/CETPs	Ganga Front Town	Treatment Technology	Designed Capacity (MLD)	Date of Inspection	Operational /Non-Operational Status	Compliance Status w.r.t Hon'ble NGT norms dated 30.04.2019	Compliance Status w.r.t MoEF&CC norms dated 13.10.2017
28	0.05 MLD STP Srikot	Srikot	FAB	0.05	23.06.2022	Operational	Non-complying FC	Non-complying FC
29	Srinagar	Srinagar	FAB	3.5	23.06.2022	Operational	Non-complying BOD, COD TSS & FC	Non-complying FC
30	1.0 MLD STP, Near ITI, Srinagar,	Srinagar	SBR	1	23.06.2022	Operational	Complying	complying
31	Kirti Nagar	Kirti Nagar	FAB	0.05	23.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying BOD, FC
32	Kirtinagar	Kirti Nagar	FAB	0.01	23.06.2022	Operational	Non-complying COD, TSS, BOD & FC	Non-complying TSS, BOD, FC
33	Bah Bazar Devprayag	Devprayag	SBT (Soil Bio-technology)	1.4	31.05.2022	Operational	Non-complying TSS, BOD, COD & FC	Non-complying TSS, BOD, FC
34	Sangam Bazar Devprayag	Devprayag	SBR	0.15	31.05.2022	Operational	Non-complying COD, FC	Non-complying FC
35	Shanti Bazar Devprayag	Devprayag	SBR	0.075	31.05.2022	Operational	Non-complying TSS, COD, &FC	Non-complying FC
36	Tapovan	Rishikesh	SBR	3.5	04.05.2022	Operational	Non-complying BOD, TSS, FC	Non-complying FC
37	Lakkarghat, Rishikesh	Rishikesh	SBR	26	26.05.2022	Operational	Complying	complying
38	Muni ki Reti	Rishikesh	MBBR	5	05.05.2022	Operational	Non-complying BOD, COD, FC	Non-complying FC
39	Chandreshwar STP	Rishikesh	MBBR	7.5	05.05.2022	Operational	Non-complying BOD, TSS, FC	Non-complying FC
40	Swarg Ashram Rishikesh	Rishikesh	SBR	3	26.05.2022	Operational	Non-complying COD, FC	Non-complying FC
41	Rishikesh, IDPL	Rishikesh	ASP	14	05.05.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying FC
42	Jagjeetpur, Haridwar (27 MLD)	Haridwar	SBR	27	09.05.2022	Operational	Non-complying FC	Non-complying FC
43	Jagjeetpur Haridwar (68 MLD)	Haridwar	SBR	68	09.05.2022	Operational	Non-complying FC	Non-complying FC

S. No.	Name of STPs/CETPs	Ganga Front Town	Treatment Technology	Designed Capacity (MLD)	Date of Inspection	Operational /Non-Operational Status	Compliance Status w.r.t Hon'ble NGT norms dated 30.04.2019	Compliance Status w.r.t MoEF&CC norms dated 13.10.2017
44	Jagjeetpur, Haridwar (18 MLD)	Haridwar	ASP	18	09.05.2022	Operational	Complying	complying
45	Sarai, Jawalapur STP (14 MLD)	Haridwar	SBR	14	11.05.2022	Operational	Non-complying COD, FC	Non-complying FC
46	Sarai, Jawalapur STP	Haridwar	SBR	18	11.05.2022	Operational	Complying	complying
47	Old Mothrowala	Dehradun	SBR	20	20.06.2022	Operational	Complying	complying
48	New Mothrowala	Dehradun	SBR	20	21.06.2022	Operational	Non-complying BOD, COD & FC	Non-complying FC
49	Kargi	Dehradun	SBR	68	21.06.2022	Operational	Non-complying FC	Non-complying FC
50	Jakhan	Dehradun	SBR	1	22.06.2022	Operational	Non-complying FC	Non-complying FC
51	Salawala	Dehradun	SBR	0.71	22.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying FC
52	Vijay Colony	Dehradun	SBR	0.42	21.06.2022	Operational	Non-complying FC	Non-complying FC
53	Indira Nagar	Dehradun	SBR	5	21.06.2022	Operational	Non-complying FC	Non-complying FC

• STPs complying to BOD Norms (<10mg/l) in Uttarakhand (April-June,2022) w.r.t. NGT and MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	BOD (≤ 10 mg/l)
1	Chamoli Ghat	Chamoli-Gopeshwar	0.76	4
2	Vivekanand Colony STP (Leesa Bend)	Chamoli-Gopeshwar	1.19	7
3	Deen Dayal Uppadyay Park	Chamoli-Gopeshwar	1.12	9
4	Pokhri, Joshimath 1.08 MLD	Joshimath	1.08	9
5	Forest Nala STP	Nandprayag	0.10	3
6	Near Police Chowki STP 01	Karanprayag	0.05	2
7	Near Ward 1 & 3 STP 05	Karanprayag	0.1	3
8	BRO Bridge STP 04	Karanprayag	0.05	8
9	Subhash Nagar STP 03	Karanprayag	0.05	6
10	Near Dart Pull STP	Rudraprayag	0.075	2
11	Army Bend (Rudra Complex) STP 02	Rudraprayag	0.1	7

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	BOD (≤ 10 mg/l)
12	Near Steel Bridge	Rudraprayag	0.125	4
13	Gyansu	Uttarkashi	2	7
14	Tehri	Tehri	5	8
15	0.05 MLD STP Srikot	Srikot	0.05	2
16	1.0 MLD STP, Near ITI, Srinagar,	Srinagar	1	6
17	Sangam Bazar Devprayag	Devprayag	0.15	7
18	Shanti Bazar Devprayag	Devprayag	0.075	8
19	Lakkarghat, Rishikesh	Rishikesh	26	5
20	Swarg Ashram Rishikesh	Rishikesh	3	9
21	Jagjeetpur, Haridwar	Haridwar	27	10
22	Jagjeetpur Haridwar	Haridwar	68	6
23	Jagjeetpur, Haridwar	Haridwar	18	3
24	Sarai, Jawalapur STP	Haridwar	14	10
25	Sarai, Jawalapur STP	Haridwar	18	7
26	Old Mothrowala	Dehradun	20	3
27	Kargi	Dehradun	68	4
28	Jakhan	Dehradun	1	4
29	Vijay Colony	Dehradun	0.42	7
30	Indira Nagar	Dehradun	5	4

• **STPs complying to BOD Norms (11-30mg/l) in Uttarakhand (April-June,2022) w.r.t. MoEF&CC norms**

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	BOD (11 mg/l to 30 mg/l)
1	Gangotri	Gangotri	1	11
2	Pokhri Bend STP	Chamoli-Gopeshwar	1.25	14
3	Sangam Nala STP	Nandprayag	0.05	12
4	Near SBI Bank STP	Rudraprayag	0.1	24
5	Baleni Road	Rudraprayag	0.05	15
6	0.075 MLD STP Srikot	Srikot	0.075	17
7	Srinagar	Srinagar	3.5	16
8	Tapovan	Rishikesh	3.5	14
9	Muni ki Reti	Rishikesh	5	13
10	Chandreshwar STP	Rishikesh	7.5	11
11	Rishikesh, IDPL	Rishikesh	14	25
12	New Mothrowala	Dehradun	20	20
13	Salawala	Dehradun	0.71	23

- STPs non-complying to BOD Norms ($\geq 30\text{mg/l}$) in Uttarakhand (April-June,2022) w.r.t. NGT and MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	BOD ($\geq 30\text{ mg/l}$)
1	Badrinath 0.01MLD STP	Badrinath	0.01	1237
2	Badrinath 0.26 MLD STP	Badrinath	0.26	196
3	Old Suspension bridge	Chamoli-Gopeshwar	0.05	31
4	Old Bridge STP 02	Karanprayag	0.1	76
5	Kirti Nagar	Kirti Nagar	0.05	42
6	Kirtinagar	Kirti Nagar	0.01	100
7	Bah Bazar Devprayag	Devprayag	1.4	40

- STPs complying to COD ($\leq 50\text{ mg/l}$) in Uttarakhand (April-June,2022) w.r.t. NGT Norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	COD ($\leq 50\text{ mg/l}$)
1	Chamoli Ghat	Chamoli-Gopeshwar	0.76	38
2	Vivekanand Colony STP (Leesa Bend)	Chamoli-Gopeshwar	1.19	44
3	Pokhri Bend STP	Chamoli-Gopeshwar	1.25	34
4	Deen Dayal Uppadyay Park	Chamoli-Gopeshwar	1.12	40
5	Pokhri, Joshimath 1.08 MLD	Joshimath	1.08	48
6	Forest Nala STP	Nandprayag	0.10	16
7	Near Police Chowki STP 01	Karanprayag	0.05	9
8	Near Ward 1 & 3 STP 05	Karanprayag	0.1	12
9	BRO Bridge STP 04	Karanprayag	0.05	30
10	Subhash Nagar STP 03	Karanprayag	0.05	29
11	Near Dart Pull STP	Rudraprayag	0.075	13
12	Army Bend (Rudra Complex) STP 02	Rudraprayag	0.1	44
13	Near Steel Bridge	Rudraprayag	0.125	29
14	Gyansu	Uttarkashi	2	33
15	0.05 MLD STP Srikot	Srikot	0.05	8
16	1.0 MLD STP, Near ITI, Srinagar,	Srinagar	1	44
17	Tapovan	Rishikesh	3.5	37
18	Lakkarghat, Rishikesh	Rishikesh	26	15
19	Chandreshwar STP	Rishikesh	7.5	44
20	Jagjeetpur, Haridwar (27 MLD)	Haridwar	27	29
21	Jagjeetpur Haridwar (68 MLD)	Haridwar	68	34
22	Jagjeetpur, Haridwar (18 MLD)	Haridwar	18	17
23	Sarai, Jawalapur STP	Haridwar	18	43
24	Old Mothrowala	Dehradun	20	26
25	Kargi	Dehradun	68	40
26	Jakhan	Dehradun	1	31
27	Vijay Colony	Dehradun	0.42	47

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	COD (≤ 50 mg/l)
28	Indira Nagar	Dehradun	5	30

• **STPs non-complying to COD (≤ 50 mg/l) in Uttarakhand (April-June,2022) w.r.t. NGT norms**

S. No.	Name of STPs/CETPs	Ganga Front Town	Designed Capacity (MLD)	COD (≥ 50 mg/l)
1	Gangotri	Gangotri	1	71
2	Badrinath 0.01MLD STP	Badrinath	0.01	1803
3	Badrinath 0.26 MLD STP	Badrinath	0.26	451
4	Old Suspension bridge	Chamoli-Gopeshwar	0.05	111
5	Sangam Nala STP	Nandprayag	0.05	59
6	Old Bridge STP 02	Karanprayag	0.1	167
7	Near SBI Bank STP	Rudraprayag	0.1	98
8	Baleni Road	Rudraprayag	0.05	55
9	Tehri	Tehri	5	60
10	0.075 MLD STP Srikot	Srikot	0.075	61
11	Srinagar	Srinagar	3.5	52
12	Kirti Nagar	Kirti Nagar	0.05	102
13	Kirtinagar	Kirti Nagar	0.01	281
14	Bah Bazar Devprayag	Devprayag	1.4	178
15	Sangam Bazar, Devprayag	Devprayag	0.15	51
16	Shanti Bazar Devprayag	Devprayag	0.075	53
17	Muni ki Reti	Rishikesh	5	55
18	Swarg Ashram Rishikesh	Rishikesh	3	52
19	Rishikesh, IDPL	Rishikesh	14	98
20	Sarai, Jawalapur STP (14 MLD)	Haridwar	14	58
21	New Mothrowala	Dehradun	20	133
22	Salawala	Dehradun	0.71	111

• **STPs complying to TSS (≤ 20 mg/l) in Uttarakhand (April-June,2022)w.r.t. NGT and MoEF&CC norms**

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	TSS (≤ 20 mg/l)
1	Gangotri	Gangotri	1	18
2	Vivekanand Colony STP (Leesa Bend)	Chamoli-Gopeshwar	1.19	BDL
3	Pokhri Bend STP	Chamoli-Gopeshwar	1.25	BDL
4	Deen Dayal Uppadyay Park	Chamoli-Gopeshwar	1.12	13
5	Pokhri, Joshimath 1.08 MLD	Joshimath	1.08	10
6	Near Police Chowki STP 01	Karanprayag	0.05	BDL
7	Subhash Nagar STP 03	Karanprayag	0.05	17
8	Near Dart Pull STP	Rudraprayag	0.075	11
9	Near Steel Bridge	Rudraprayag	0.125	20
10	Gyansu	Uttarkashi	2	12

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	TSS (≤ 20 mg/l)
11	0.05 MLD STP Srikot	Srikot	0.05	BDL
12	1.0 MLD STP, Near ITI	Srinagar	1	18
13	Sangam Bazar, Devprayag	Devprayag	0.15	11
14	Lakkarghat, Rishikesh	Rishikesh	26	BDL
15	Muni ki Reti	Rishikesh	5	15
16	Swarg Ashram Rishikesh	Rishikesh	3	12
17	Jageetpur, Haridwar (27 MLD)	Haridwar	27	BDL
18	Jageetpur Haridwar (68 MLD)	Haridwar	68	15
19	Jageetpur, Haridwar (18 MLD)	Haridwar	18	BDL
20	Sarai, Jawalapur STP (14 MLD)	Haridwar	14	16
21	Sarai, Jawalapur STP	Haridwar	18	BDL
22	Old Mothrowala	Dehradun	20	BDL
23	New Mothrowala	Dehradun	20	BDL
24	Kargi	Dehradun	68	BDL
25	Jakhan	Dehradun	1	11
26	Vijay Colony	Dehradun	0.42	15
27	Indira Nagar	Dehradun	5	BDL

• STPs complying to TSS (20 mg/l - 100 mg/l) in Uttarakhand (April-June,2022) w.r.t. MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	TSS (20 mg/l - 100 mg/l)
1	Old Suspension bridge	Chamoli-Gopeshwar	0.05	46
2	Chamoli Ghat	Chamoli-Gopeshwar	0.76	55
3	Forest Nala STP	Nandprayag	0.10	56
4	Sangam Nala STP	Nandprayag	0.05	70
5	Old Bridge STP 02	Karanprayag	0.1	53
6	Near Ward 1 & 3 STP 05	Karanprayag	0.1	51
7	BRO Bridge STP 04	Karanprayag	0.05	26
8	Near SBI Bank STP	Rudraprayag	0.1	72
9	Army Bend (Rudra Complex) STP 02	Rudraprayag	0.1	21
10	Baleni Road	Rudraprayag	0.05	64
11	Tehri	Tehri	5	21
12	0.075 MLD STP Srikot	Srikot	0.075	54
13	Srinagar	Srinagar	3.5	46
14	Kirti Nagar	Kirti Nagar	0.05	80
15	Shanti Bazar Devprayag	Devprayag	0.075	26
16	Tapovan	Rishikesh	3.5	24
17	Chandreshwar STP	Rishikesh	7.5	23
18	Rishikesh, IDPL	Rishikesh	14	62

19	Salawala	Dehradun	0.71	35
----	----------	----------	------	----

- STPs non-complying to TSS (≥ 100 mg/l) in Uttarakhand (April-June,2022) w.r.t. MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	TSS (≥ 100 mg/l)
1	Badrinath 0.01MLD STP	Badrinath	0.01	909
2	Badrinath 0.26 MLD STP	Badrinath	0.26	113
3	Kirtinagar	Kirti Nagar	0.01	203
4	Bah Bazar Devprayag	Devprayag	1.4	118

- STPs complying to FC (≤ 230 MPN/100 ml) in Uttarakhand (April-June,2022) w.r.t. NGT and MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	FC (≤ 230 MPN/100 ml)
1	Gangotri	Gangotri	1	<1.8
2	Pokhri, Joshimath	Joshimath	1.08	20
3	Gyansu	Uttarkashi	2	<1.8
4	1.0 MLD STP, Near ITI, Srinagar,	Srinagar	1	200
5	Lakkarghat, Rishikesh	Rishikesh	26	22
6	Jagjeetpur, Haridwar (18 MLD)	Haridwar	18	1.8
7	Sarai, Jawalapur STP	Haridwar	18	<1.8
8	Old Mothrowala	Dehradun	20	230

- STPs complying to FC (230 - 1000 MPN/100 ml) in Uttarakhand (April-June,2022) w.r.t. MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	FC (230 - 1000 MPN/100 ml)
1	Deen Dayal Upadhyay Park	Chamoli - Gopeshwar	1.12	470

- STPs non-complying to FC (≥ 1000 MPN/100 ml) in Uttarakhand (April-June,2022) w.r.t. MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	FC (≥ 1000 MPN/100 ml)
1	Badrinath 1.0 MLD STP	Badrinath	1	11×10^5
2	Badrinath 0.01MLD STP	Badrinath	0.01	27×10^{10}
3	Badrinath 0.26 MLD STP	Badrinath	0.26	17×10^6
4	Old Suspension bridge	Chamoli-Gopeshwar	0.05	22×10^5
5	Chamoli Ghat	Chamoli-Gopeshwar	0.76	22×10^4
6	Vivekanand Colony STP (Leesa Bend)	Chamoli-Gopeshwar	1.19	1100
7	Pokhri Bend STP	Chamoli-Gopeshwar	1.25	33000
8	Forest Nala STP	Nandprayag	0.10	7800
9	Sangam Nala STP	Nandprayag	0.05	110000
10	Near Police Chowki STP 01	Karanprayag	0.05	20×10^4
11	Old Bridge STP 02	Karanprayag	0.1	110000
12	Near Ward 1 & 3 STP 05	Karanprayag	0.1	68×10^4

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	FC (≥ 1000 MPN/100 ml)
13	BRO Bridge STP 04	Karanprayag	0.05	3300
14	Subhash Nagar STP 03	Karanprayag	0.05	7800
15	Near SBI Bank STP	Rudraprayag	0.1	23 x 10 ⁷
16	Near Dart Pull STP	Rudraprayag	0.075	3300
17	Army Bend (Rudra Complex) STP 02	Rudraprayag	0.1	2200
18	Near Steel Bridge	Rudraprayag	0.125	17x10 ³
19	Baleni Road	Rudraprayag	0.05	1400
20	Tehri	Tehri	5	22x10 ⁵
21	0.075 MLD STP Srikot	Srikot	0.075	39x10 ³
22	0.05 MLD STP Srikot	Srikot	0.05	2000
23	Srinagar	Srinagar	3.5	13x10 ⁵
24	Kirti Nagar	Kirti Nagar	0.05	13x10 ⁸
25	Kirtinagar	Kirti Nagar	0.01	39x10 ⁷
26	Bah Bazar Devprayag	Devprayag	1.4	70x 10 ⁴
27	Sangam Bazar Devprayag	Devprayag	0.15	11x 10 ⁴
28	Shanti Bazar Devprayag	Devprayag	0.075	78000
29	Tapovan	Rishikesh	3.5	54 x 10 ⁷
30	Muni ki Reti	Rishikesh	5	27x10 ³
31	Chandreshwar STP	Rishikesh	7.5	34000
32	Swarg Ashram Rishikesh	Rishikesh	3	21x10 ⁵
33	Rishikesh, IDPL	Rishikesh	14	23x10 ⁴
34	Jagjeetpur, Haridwar (27 MLD)	Haridwar	27	31000
35	Jagjeetpur Haridwar (68 MLD)	Haridwar	68	2000
36	Sarai, Jawalapur STP (14 MLD)	Haridwar	14	33000
37	New Mothrowala	Dehradun	20	24000
38	Kargi	Dehradun	68	17X10 ³
39	Jakhan	Dehradun	1	92X10 ⁴
40	Salawala	Dehradun	0.71	92X10 ⁶
41	Vijay Colony	Dehradun	0.42	26X10 ⁴
42	Indira Nagar	Dehradun	5	1700