

Sr. No.	Industry	Parameter	Standards
1	2	3	4
	(ii) Non-continuous process (less than 20 MT/day)		Disposal via Septic tank
	(b) Biscuit Production		
	(i) 10 T/day & above	pH	6.5 - 8.5
		BOD ¹ [3days at 27°C]	300
	D. Confectioneries	EFFLUENTS	
	(a) 4 T/day and above	pH	6.5 - 8.5
		Suspended Solids	50
		Oil and Grease	10
		BOD ¹ [3days at 27°C]	30
	(b) Below 4 T/day		Disposal via Septic Tank
	Note : To ascertain the category of 'unit fails' the average of daily production and waste water discharge for the preceding 30 operating days from the date of sampling shall be considered.		
	* The emission from the boiler house shall conform to the standards already prescribed under E(P) Act, 1986 vide Notification No. GSR 742(E) dated 30.8.90.		
52.	*JUTE PROCESSING INDUSTRY :	EFFLUENTS	Concentration in mg/l except pH and Water consumption
		pH	5.5 - 9.0
		BOD ¹ [3days at 27°C]	30
		Suspended Solids	100
		Oil and Grease	10
		Water Consumption	1,60 Cum/Ton of product produced.

¹ Substituted by Rule 2 of the Environment (Protection) Amendment Rules, 1996 notified by G.S.R.176(E), dated 2.4.1996 may be read as BOD (3 days at 27°C) wherever BOD 5 days 20°C occurred.

Sr. No.	Industry	Parameter	Standards
1	2	3	4
	<p>Note :</p> <p>1. Water Consumption for the Jute processing industry will be 1.5 Cum/Ton of product from January, 1992.</p> <p>2. At the present no limit for colour is given for liquid effluent. However, as far as possible colour should be removed.</p> <p>* Stack emissions from boiler house shall conform to the standards already prescribed under Environment (Protection) Act, 1986, vide Notification No. GSR 742(E), dated 30.08.90.</p>		
53.	LARGE PULP & PAPER NEWS PRINT/ RAYON GRADE PLANTS OF [CAPACITY ABOVE 24000 MT PER ANNUM]	EFFLUENTS	Concentration in mg/l except pH and TOCL
		pH	7.0 – 8.5
		BOD ² [3 days at 27°C]	30
		COD	350
		Suspended Solids	500
		³ [Absorbable Organic Halogens (AOX) in effluent discharge	1.5 kg/ton of product with effect from the date of publication of this notification. 1.0 kg/ton of product with effect from the 1 st day of March, 2008.]
		Flow (Total Waste Water Discharge)	
		** (i) Large Pulp & Paper	200 Cum/Ton of Paper produced
		(ii) Large Rayon Grade Newsprint	150 Cum/Ton of Paper produced.
54.	SMALL PULP AND PAPER Paper Plant of Capacity upto 24000 MT/Annum : Category :	EFFLUENT	
	A. *Agrobased	Total waste water discharge	200 cum/Ton of paper produced
	B. **Waste paper based	Total waste water discharge	75 cum/Ton of paper produced

¹ Substituted by Rule 2(ii) (a) of the Environment (Protection) Third Amendments Rules, 2005 notified vide Notification No.G.S.R.546(E), dated 30.8.2005.

² Substituted by Rule 2 of the Environment (Protection) Amendment Rules, 1996 notified by G.S.R.176(E), dated 2.4.1996 may be read as BOD (3 days at 27°C) wherever BOD 5 days 20°C occurred

³ Substituted by Rule 2(ii) (b) of the Environment (Protection) Third Amendments Rules, 2005 notified vide Notification No.G.S.R.546(E), dated 30.8.2005

** The Standards with respect of total wastewater discharge for the large pulp and paper mills be established from 1992, will meet the standards of 100 cum/Ton of paper produced.