

By Speed Post

July 16 2021

F.NO.CP-11/57/2021-IPC-III-HO-CPCB-HO 3556

To

M/s Nahar Spinning Mills Limited (Dyeing Unit).
Dhandari Kalan, G.T Road,
Ludhiana East, Ludhiana, Punjab

Sub: Inspection of M/s Nahar Spinning Mills Limited (Dyeing Unit). Dhandari Kalan, G.T Road,
Ludhiana East, Ludhiana, Punjab -Regd.

Sir,


It is to inform you that M/s Nahar Spinning Mills Limited (Dyeing Unit). Dhandari Kalan, G.T Road, Ludhiana East, Ludhiana, Punjab was inspected by a team of CPCB officials on 24.06.2021 to verify the compliance status of the industries under surprise inspection program. It was observed that the concentration of (TDS-3308 mg/l, against 2100mg/l) was exceeding effluent discharge norms. Based on the observations made by the inspection team, the following recommendations are required to be complied by the unit:

1. The Unit should ensure regular operation & maintenance of ETP so as to achieve the prescribed discharge standards and submit analysis report of treated effluent from EPA approved lab to CPCB within 30 days of receipt of this letter.
2. The unit shall carry out adequacy assessment of its ETP through reputed Institute/Organization, preferably IITs/NITs/NEERI etc., and accordingly upgrade/augment the ETP as per the recommendation of the report so as to meet the prescribed discharge standards.
3. The Unit shall obtain permission from CGWA for groundwater abstraction.
4. The Unit shall store all types of Hazardous Waste and empty chemical container under dedicated area with proper marking as per the provisions of Hazardous & Other Waste Rules, 2016.

In this context, it is requested to ensure compliance of the aforesaid recommendations of the inspection team and terms & conditions of the consent to operate granted by Punjab PCB and submit ATR to CPCB at the earliest.

This issues with the approval of the Competent Authority.

Yours faithfully,



(P.K. Mishra)
Additional Director &
Divisional Head- IPC-III

o/c

Copy to:

1. **The Member Secretary,** : With a request to keep this under surveillance for ensuring complete & continuous compliance of stipulated norms & terms & conditions of consent order
Punjab Pollution Control Board
(PPCB)Vatavaran Bhawan, Nabha
Road, Patiala - 147 001
2. **The Regional Director,** : For follow-up action please.
Regional Directorate, CPCB
Second Floor, Telephone Exchange,
Sector 49, Chandigarh - 160047

केंद्रीय प्रदूषण नियंत्रण बोर्ड
निर्गत NSM/o/c
दिनांक 29/7/2021

(P.K. Mishra)

16/07/21