

List of Manufacturers of Diesel Gensets (Upto 1000 kVA) who have obtained Conformity of Production (COP) Verification Certificate for Noise Limits

Certificates for Noise Limits Certification Agency: International Centre for Automotive Technology, Manesar

COP Year: 1st January to 31st December 2019

Valid upto: 31st December 2020

Sr. No.	Name & Address of Genset Manufacturer	Genset Model Sr. No.	Engine Make	Genset Model (Parent & Variant)	kVA Rating	Production during last year	Type Approval Certificate No. & Date	Noise Level dB(A)	Latest COP Certificate No. & Date
1	Rai Prexim India Pvt. Ltd. Plot No 132, Ecotech-1 Extension, Greater Noida-201310, Dist. Gautam Budh Nagar, U.P	1	AB Volvo Penta	RP 250/P	250	124	CT0VK 0590 Dated- 28/10/2015	72.8	CT0N00098 dated 04-Nov-19
		2		RP 415/P RP 320/V RP 380/V	415 320 380		CT0VK 0588 Dated- 28/10/2015	74.8	
		3		RP 500/P	500		CT0VK 0556 Dated- 12/10/2015	74.0	
		4		RP 650/P RP 600/V	650 600		CT0VK 0628 Dated- 19/11/2015	74.6	
2	JCB Power Products India Pvt. Ltd. 23/7,Mathura Road , Ballabgarh Haryana- 121 004 (INDIA)	1	JCB	G63QI	63	474	CT0NN 0014 Dated- 08/05/2018	72.9	CT0N00103 dated 06-Dec-19
		2		G100QI G80QI	100 80		CT0NN 0016 Dated- 10/05/2018	73.6	
		3	Mahindra Heavy Engines	G125QI	125		CT0NN 0018 Dated- 10/05/2018	74.8	
		4		G160QI	160		CT0VM 0847 Dated- 21/06/2017	73.4	
		5		G200QI G180QI	200 180		CT0NN 0079 Dated- 10/12/2018	74.1	

3	Maas Generators Pvt. Ltd. 42D, HSIDC Shed/Sector- 37/Phase-VI, UdyogVihar, Gurgaon- 122001, Haryana	1	Eicher	MGPL-7.5/SP MGPL-5/SP	7.5 5	461	CT0VK 0108 Dt. - 25/02/2015	71.6	CTON00111 dated 30-Dec-19
		2		MGPL-10/SP/TP MGPL-7.5/SP/TP	10 7.5		CT0VJ 0352 Dt. - 15/07/2014	70.9	
		3		MGPL-15/SP/TP MGPL-12.5/SP/TP	15 12.5		CT0VJ 0354 Dt. - 15/07/2014	73.4	
		4		MGPL-20/SP/TP MGPL-15/SP/TP	20 15		CT0VJ 0356 Dt. - 15/07/2014	71.6	
		5		MGPL-25/SP/TP MGPL-20/SP/TP	25 20		CT0VJ 0358 Dt. - 15/07/2014	74	
		6		MGPL-35/SP/TP MGPL-30/SP/TP	35 30		CT0VJ 0360 Dt. - 15/07/2014	71.5	
		7		MGPL-45-A/SP/TP MGPL-40-A/SP/TP	45 40		CT0VK 0723 Dt. - 30/12/2015	70.7	
		8		MGPL-62.5/SP/TP MGPL-50/SP/TP	62.5 50		CT0VJ 0364 Dt. - 15/07/2015	72.6	
		9		MGPL-82.5/TP MGPL-75/TP	82.5 75		CT0VK 0226 Dt. - 02/06/2015	71.6	

		10		MGPL-125/TP MGPL-100/TP	125 100		CTOVK 0224 Dt. - 02/06/2015	70.9	
4	ICON Power Solutions India Pvt. Ltd. Plot No 112-113, Sector- 5, Industrial Estate, IMT- Manesar, Gurugram	1	Eicher	ICON/7.5/SP ICON/5.25/SP	7.5 5.25	253	CTONN 0028 Dt. - 02/07/2018	70.6	CTONN 00117 dated 31-Dec-19
		2		ICON/10/SP/TP ICON/7.5/SP/TP	10 7.5		CTONN 0022 Dt. - 02/07/2018	71.2	
		3		ICON/15/SP/TP ICON/12.5/SP/TP	15 12.5		CTONN 0026 Dt. - 02/07/2018	72.2	
		4		ICON/20/T/SP/TP ICON/15/T/SP/TP	20 15		CTONN 0024 Dt. - 02/07/2018	72.2	
		5		ICON/25/SP/TP ICON/20/SP/TP	25 20		CTONN 0030 Dt. - 02/07/2018	69.8	
		6		ICON/35/SP/TP ICON/30/SP/TP	35 30		CTONN 0020 Dt. - 02/07/2018	70.3	
		7		ICON/45/SP/TP ICON/40/SP/TP	45 40		CTONN 0032 Dt. - 02/07/2018	71.0	
		10							
5	Rishabh Engineering Company 1036, Hari Nagar, Meerut Road, Ghaziabad, Uttar Pradesh-201001	1	Tata	RTS125 RT-100 RT-83	125 100 88	117	CTONN 0012 Dt. 08/05/2018	73.9	CTONN 00115 dated 31-Dec-19
		2		RT-82.5 RT-62.5 RT-75	82.5 62.5 75		CTOVK 0080 Dt. 25/02/2015	74.3	
		3		RT-40 RT-35 RT-30 RT-28	40 35 30 28		Exemption taken from CPCB	CTOVK 0078 Dt. 25/02/2015	