

**LIST OF PETROL AND / OR KEROSENE DRIVEN GENSET MANUFACTURERS, WHO HAVE OBTAINED CONFORMITY OF PRODUCTION VERIFICATION CERTIFICATES (COP) FOR NOISE COMPLIANCE**

As per Govt. of India. Ministry of Environment notification GSR 535 (E), dated 07.08.2013 and its amendments, at serial number 88, every manufacturer or assembler or importer (hereinafter referred to as 'manufacturer') of generator set, driven on Petrol or Kerosene, (hereinafter referred to as 'product') to which these regulations apply must have valid certificates of Type Approval and also valid certificates of Conformity of Production for each COP year, for all the product models

COP Year: 1<sup>st</sup> September –31<sup>st</sup> August next year

Noise Standard

The noise limit for new generator sets run with petrol and kerosene shall be as follows:-

	Noise Limits
Sound Power Level $L_{wa}$	86 dBA

Agency for testing and issuing certificate(s)

- a) The Automotive Research Association of India, Pune (Maharashtra) [\(CLICK HERE\)](#)
- b) The International Centre for Automotive Technology, Manesar (Haryana) [\(CLICK HERE\)](#)
- c) The Indian Oil Corporation, Research and Development Centre, Faridabad (Haryana);
- d) The Indian Institute of Petroleum, Dehradun (Uttarakhand); and
- e) The Vehicle Research Development Establishment, Ahmednagar (Maharashtra).

For details of result in the last COP year click the above links [↑](#)