



Speed Post

CPCB/IPC-VII/CETP-Delhi/14292

2nd March, 2022

To

The Chairman
Delhi Pollution Control Committee
4th Floor, ISBT Building,
Kashmere Gate
Delhi - 110006

Sub: Directions under Section 18 (1) (b) of Water (Prevention and Control of Pollution) Act, 1974, regarding non-compliance status of M/s CETP, Mangolpuri Industrial Area, Phase-I, Delhi-110083.

WHEREAS, amongst others, under Section 17 of Water (Prevention and Control of Pollution) Act, 1974, one of the functions of State Pollution Control Boards (SPCBs) (or Pollution Control Committee for Union Territories), constituted under the Water (Prevention and Control of Pollution) Act, 1974, is to plan a comprehensive programme for the prevention, control and abatement of pollution of streams and wells in the concerned State/UT and to secure the execution thereof; and

WHEREAS, amongst others, under Section 16 of the Water (Prevention and Control of Pollution) Act, 1974, one of the functions of the Central Pollution Control Board (CPCB) constituted under the Water (Prevention and Control of Pollution) Act, 1974, is to coordinate activities of the State Pollution Control Boards (SPCBs)/Pollution Control Committees (PCCs) and to provide technical assistance and guidance to SPCBs/PCCs; and

WHEREAS, amongst others, under Section 16 of the Water (Prevention and Control of Pollution) Act, 1974, one of the functions of the CPCB is to promote cleanliness of streams and wells in different areas of the States; and

WHEREAS, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries, Common Effluent Treatment Plants (CETPs) and Sewage Treatment Plants (STPs) under the Environment (Protection) Act, 1986 and the rules framed thereunder; and

WHEREAS, there is a need to inculcate the habit of self-monitoring within the CETPs for complying with the prescribed standards and this can be achieved by installing Online Continuous Emission Monitoring System (OCEMS); and

WHEREAS, M/s CETP, Mangolpuri Industrial Area, Phase-I, Delhi-110083 (hereinafter referred as CETP), was inspected by a team of officials from CPCB on 11/11/2021 and the following observations were made:

- i. CETP was working with 1.9 MLD of actual flowrate against the designed capacity of 2.4 MLD.
- ii. CETP was operating without valid consents. The Consent to Operate was expired on 28/04/2021 and CETP applied for renewal of same on 17/04/2021.
- iii. OCEMS was not functional on the day of visit. CETP, vide letter dated 15/09/2021, has earlier informed CPCB regarding malfunctioning of BOD, COD and TSS sensors. The transmission of OCEMS data to CPCB server was resumed from 26/11/2021.
- iv. The laboratory analysis of treated effluent samples shows that the quality parameters viz., FDS and NO₃-N as 3776 mg/l and 10.8 mg/l, respectively, are exceeding the discharge standards prescribed by DPCC.
- v. CETP is storing the Sludge/Hazardous Waste in its premises. Sludge was found stored in filter press premises. As informed, the CETP has been in the process of getting membership of HWTSDI, established & operated by M/s Tamil Nadu Waste Management Limited located at Bawana Industrial Area, Narela, Delhi, for regular disposal of Hazardous waste.

AND NOW THEREFORE, in exercise of powers conferred under Section 18 (1) (b) of the Water (Prevention and Control of Pollution) Act, 1974, DPCC is hereby directed to take appropriate action for compliance of the following directions:

1. CETP shall operate appropriately and take corrective actions to comply with the environmental standards.
2. CETP shall operate with valid Consents and Authorizations.
3. The CETP shall obtain membership of HWTSDI for safe disposal of hazardous waste.
4. CETP shall ensure proper functioning of OCEMS and continuous data transmission to CPCB/DPCC.
5. DPCC shall ensure closure of individual member units that do not have adequate treatment facilities to comply with the norms.
6. DPCC shall take action, as deemed fit, including levying of environmental compensation against non-complying CETP or member industries.

Compliance of the directions shall be submitted to CPCB within 15 days from the receipt of the directions.

15/11/21
(Tanmay Kumar)
Chairman

AAgwal

02/07/2022

Copy to:

1. **The Joint Secretary (CP Division)** : for information, please
Ministry of Environment, Forests and
Climate Change
Prithvi Wing, 2nd Floor, Room No. 216
Indira Paryavaran Bhavan, Aliganj
Jor Bagh Road,
New Delhi- 110003

2. **The Regional Director** : for follow-up, please
Central Pollution Control Board
BSNL Exchange, 2nd floor
Sector 49-C,
Chandigarh-160047

3. **Divisional Head, IT,** : for uploading on CPCB
CPCB, Delhi website, please


(Prashant Gargava)
Member Secretary