

**Speed Post**

B-190198/WQM-II(RG)/CPCB/Sugar/33/2016-17

March 26, 2018

18588

28

To,

**M/s Bisalpur Kisan Sahkari Chini Mills Ltd.,  
Bisalpur, Pilibhit,  
Uttar Pradesh**

**DIRECTION UNDER SECTION 5 OF THE ENVIRONMENT (PROTECTION) ACT, 1986-  
CLOSURE NOTICE THEREOF**

**WHEREAS**, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act, 1986 and the rules framed there under; and

**WHEREAS**, the Ministry of Environment & Forests, Govt. of India, vide notification S.O.157(E) of 27.02.1996 has delegated powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board (CPCB), to issue direction to any industry, Municipal Corporation, Municipal Council, Cantonment Board to any local or other Authority for the violation of emission and effluent standards notified under the Environment (Protection) Rules, 1986; and

**WHEREAS**, it is obligatory on the part of industries to install effluent treatment plants (ETPs) to comply with the effluent discharge standards as notified under the Environment (Protection) Act, 1986 and the Rules framed thereunder and also to meet the consent conditions granted by State Pollution Control Board (SPCBs) / Pollution Control Committees (PCCs); and

**WHEREAS**, M/s Bisalpur Kisan Sahkari Chini Mills Ltd., Bisalpur, Pilibhit, U.P. (hereinafter referred as 'the Unit') is involved in the process of sugar manufacturing from crushing of cane; and

**WHEREAS**, CPCB issued direction dated 06.06.2017 under section 5 of Environment (Protection) Act, 1986 to the Unit to remain closed till compliance with the following directions:

1. i. The Unit shall submit the following reports to CPCB duly validated by reputed institutions like National Sugar Institute, Kanpur/Vasandada Sugar Institute, Pune /IITs within 60 days;
  - a) ETP adequacy assessment reports;
  - b) time bound action plan for ETP augmentation & upgradation upto tertiary treatment level; to comply with the standards notified G.S.R. 35 (E), MoEF&CC, January 14, 2016 for effluent disposal, & waste water conservation.

**(Contd..2/-)**

- c) water audit and mass balance report to establish waste water generation rate;
  - d) action Plans to achieve the notified effluent discharge quality and generation standards.
  - e) irrigation management plan as per the new notified standards on January 14, 2016; and
- ii. The Unit shall restrict the storage capacity of lined lagoon upto 15 days of effluent generation.
  - iii. The Unit shall meet the BOD-30mg/l standards for discharging any effluent on land /surface water body whereas effluent stored in lined lagoons/tanks of capacity not more than 15 days shall comply with BOD-100 mg/l standards.
2. The Unit shall stabilize the ETP by September 2017 before commencing of the new crushing season. The unit will not be allowed to resume manufacturing operations till stabilization of ETP system.
  3. The Unit shall upgrade of process technology, ETP system & adapt the best practice in a time bound manner and submit a report to CPCB before starting the next crushing season.
  4. The Unit shall seek permission from CPCB, after compliance with the above mentioned directions before resumption of manufacturing operations.

**AND WHEREAS**, the CPCB received adequacy assessment report vide letter dt. 06.10.2017 on 09.10.2017 from the unit prepared by VSI, Pune; and

**WHEREAS**, CPCB issued direction dated 08.11.2017 under section 5 of Environment Protection Act, 1986 to the Unit to comply with the following directions;

1. The Unit shall start its operation only after obtaining valid consent from the concerned State Pollution Control Board.
2. The Unit shall submit implementation status of action plan before 30.11.2017.
3. The Unit shall install & Commission ETP system upto tertiary treatment level including adequate treatment system for spray pond overflow effluent in case of double sulphitation process (Brine recovery system to be installed in case of sugar refinery having Ion Exchange Process for sugar melt de-colorization).
4. The Unit having high pressure boiler (>45 Kg/cm<sup>2</sup>) shall install & Commission Condensate Polishing Unit (CPU) within 45 days for treatment of condensate water to ensure its reuse & recycle within the process.
5. The Unit shall restrict the effluent storage capacity to 15 days.
6. The Unit shall utilise treated effluent meeting the prescribed norms for irrigation as per the irrigation management plan validated by expert institutions namely, NSI, Kanpur/ VSI, Pune/ Agricultural Institutions.

**(Contd..3/-)**

7. The Unit shall implement the observation and recommendation of the adequacy report within 45 days.
8. The Unit shall get the verification of implement status of the recommendation of adequacy report including ETP performance assessment & effluent generation assessment done by the same institute which carried out adequacy assessment and submit the report to CPCB within 45 days from date of resumption of manufacturing operations.
9. The analysis result of the treated effluent shall also be submitted within 45 days through EPA recognised laboratories.
10. If the Unit fails to provide the verification report duly validated by the expert institutions, the Unit shall automatically stop all its manufacturing operations after 45 days from date of resumption of manufacturing operations.

**AND WHEREAS**, the Unit replied vide letters dated 29.11.2017 & 07.12.2017 regarding the implementation of recommendations of the adequacy report were examined; and

**AND WHEREAS**, the Unit (M/s Bisalpur Kisan Sahkari Chini Mills Ltd., Bisalpur, Pilibhit, U.P.) was inspected on 01.02.2018 by officials from CPCB, Delhi and following observations are made;

1. During the inspection, the ETP was found operational.
2. The Unit has applied for valid consent under Water (Prevention and Control of Pollution) Act, 1974 & Air (Prevention and Control of Pollution) Act, 1981 to UPPCB.
3. The treated effluent from secondary clarifier outlet was found to be discharged directly into the drain.
4. Inlet channel of the ETP was found broken to bypass the untreated effluent to outside the nallah.
5. Spray pond tank was also found broken to bypass the spray pond overflow without any treatment to outside the nallah.
6. The analysis of treated effluent sample shows pH-6.71, as against norms of 5.5-9.0, **BOD-965 mg/l** against norms of 30 mg/l, **COD- 3240 mg/l** against norms of 250 mg/l, **TSS- 290 mg/l** against norms of 30 mg/l at outlet of the ETP which indicates non-compliance w.r.t. BOD, COD & TSS with the effluent discharge norms prescribed under Environment (Protection) Rules, 1986.
7. The analysis of treated effluent sample from lagoon is also found non-compliance w.r.t. **BOD-275 mg/l** against norms of 100 mg/l, **COD- 564 mg/l** against norms of 250 mg/l, **TSS- 143 mg/l** against norms of 100 mg/l for land discharge.
8. The MLSS in aeration tank is found 457 mg/l which indicates unstabilised Activated Sludge Process system due to poor operation and maintenance of ETP system.
9. The Unit has not maintained the log book for the water extraction from the borewells, ETP inlet and outlet flow, spray pond overflow, disposal of ETP sludge, Press mud, Boiler ash, used oil etc.

(Contd..4/-)



10. The Unit has not submitted the irrigation management plan.
11. The Unit has also not submitted the analysis result of the treated effluent within 45 days from the dated of resumption of its operation through EPA recognised laboratories.
12. The Unit has not submitted the revalidated ETP adequacy assessment report within 45 days from the dated of resumption.of its operation to CPCB.

**It is evident that the aeration tank of ETP system is not properly stabilised due to poor operation and maintenance of ETP system and untreated/ partially treated effluent is being discharged by the Unit, posing potential threat to surface water/ground water quality.**

**AND NOW, THEREFORE,** in view of above observations and in exercise of the powers delegated to the Chairman, CPCB under section 5 of the Environment (Protection) Act, 1986, the unit (M/s Bisalpur Kisan Sahkari Chini Mills Ltd., Bisalpur, Pilibhit, U.P.) is directed to **close down its manufacturing operations immediately** and shall comply with the following directions;

1. The Unit is directed to close down its Sugar manufacturing operations with immediate effect and shall not resume its operations.
2. The Unit shall dismantle the bypass arrangement and stop untreated effluent discharge immediately.
3. The Unit shall install & Commission ETP system upto tertiary treatment level including adequate treatment system for spray pond overflow effluent in case of double sulphitation process.
4. The Unit having high-pressure boiler (>45 Kg/cm<sup>2</sup>) shall install & Commission Condensate Polishing Unit (CPU) within 45 days for treatment of condensate water to ensure its reuse & recycle within the process and shall meet the notified standard.
5. The Unit shall restrict the effluent storage capacity to 15 days.
6. The Unit shall submit irrigation management plan and utilise treated effluent meeting the prescribed norms for irrigation as per the irrigation management plan validated by expert institutions namely, NSI, Kanpur/ VSI, Pune/ Agricultural Institutions.
7. The Unit shall get the verification of implement status of the recommendation of adequacy report including ETP performance assessment & effluent generation assessment done by the same institute which carried out adequacy assessment and submit the report to CPCB.
8. The Unit shall submit the revalidated ETP adequacy assessment report to CPCB.
9. The Unit shall inform to CPCB about the Closure of operation immediately.
10. The Unit shall obtain valid consent under Water/Air Acts from UPPCB and submit the copies of valid consent to CPCB.
11. The Unit shall seek permission from CPCB before resumption of manufacturing operations.

**(Contd..5/-)**

In case of default in compliance with the above directions, CPCB will be constrained to initiate action against the Unit (**M/s Bisalpur Kisan Sahkari Chini Mills Ltd., Bisalpur, Pilibhit, U.P.**) without giving any further notice in accordance with the provisions of the Environment (Protection) Act, 1986.

(S. P. SINGH PARIHAR)  
CHAIRMAN

**Copy to:**

**1. The Chairman**

Uttar Pradesh Pollution Control Board,  
Building No. TC-12V, Vibhuthi Khand,  
Gomti Nagar, Lucknow – 226 010

:With request to ensure compliance of the directions.

**2. Joint Secretary (CP Division)**

Ministry of Environment, Forest & C.C  
Prithvi Block, Indira Paryavaran Bhawan,  
Jorbagh Road, New Delhi – 110 003

:For kind information, please.

**3. The District Magistrate**

Pilibhit, U.P.

:With request to ensure closure of the unit in compliance of the directions

**4. The Superintending Engineer**

Madhyanchal Vidyut Vitran Nigam Ltd.  
Pilibhit, U.P.

:With a direction to disconnect power supply

**5. The Regional Director**

Regional Directorate  
Central Pollution Control Board, PICUP Bhawan,  
Ground Floor, Vibhuti Khand, Gomti Nagar,  
Lucknow – 226 010

:For follow up and ensuring compliance

**6. The In-charge, IT Division, CPCB**

**7. Master file/Guard file, WQM II, CPCB Delhi**



(A SUDHAKAR)  
MEMBER SECRETARY