

**Speed Post**

B-190197/WQM-II(RG)/CPCB/Sugar/16 /2016-17

May 02<sup>nd</sup>, 2018  
10

To,

**M/s Doiwala Sugar Company Ltd.**  
**Doiwala, Dehradun,**  
**Uttarakhand-248140**

**DIRECTION UNDER SECTION 5 OF THE ENVIRONMENT (PROTECTION) ACT, 1986-  
NOTICE THEREOF**

**WHEREAS**, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act, 1986 and the rules framed there under; and

**WHEREAS**, the Ministry of Environment & Forests, Govt. of India, vide notification S.O.157(E) of 27.02.1996 has delegated powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board (CPCB), to issue direction to any industry, Municipal Corporation, Municipal Council, Cantonment Board to any local or other Authority for the violation of emission and effluent standards notified under the Environment (Protection) Rules, 1986; and

**WHEREAS**, it is obligatory on the part of industries to install effluent treatment plants (ETPs) to comply with the effluent discharge standards as notified under the Environment (Protection) Act, 1986 and the Rules framed thereunder and also to meet the consent conditions granted by State Pollution Control Board (SPCBs) / Pollution Control Committees (PCCs); and

**WHEREAS**, M/s Doiwala Sugar Company Ltd., Doiwala, Dehradun, Uttarakhand (hereinafter referred as 'the Unit') is involved in the process of sugar manufacturing from crushing of cane; and

**WHEREAS**, CPCB issued direction dated 16.06.2017 under section 5 of Environment Protection Act, 1986 to the Unit to remain closed till compliance with the following directions:

1. i. The Unit shall submit the following reports to CPCB duly validated by reputed institutions like National Sugar Institute, Kanpur/Vasandada Sugar Institute, Pune /IITs within 60 days;
  - a) ETP adequacy assessment reports;

**(Contd..2/-)**

- b) time bound action plan for ETP augmentation & upgradation upto tertiary treatment level; to comply with the standards notified G.S.R. 35 (E), MoEF&CC, January 14, 2016 for effluent disposal, & waste water conservation.
  - c) water audit and mass balance report to establish waste water generation rate;
  - d) action Plans to achieve the notified effluent discharge quality and generation standards.
  - e) irrigation management plan as per the new notified standards on January 14, 2016; and
- ii. The Unit shall restrict the storage capacity of lined lagoon upto 15 days of effluent generation.
  - iii. The Unit shall meet the BOD-30mg/l standards for discharging any effluent on land /surface water body whereas effluent stored in lined lagoons/tanks of capacity not more than 15 days shall comply with BOD-100 mg/l standards.
2. The Unit shall stabilize the ETP by September 2017 before commencing of the new crushing season. The unit will not be allowed to resume manufacturing operations till stabilization of ETP system.
  3. The Unit shall upgrade of process technology, ETP system & adapt the best practice in a time bound manner and submit a report to CPCB before starting the next crushing season.
  4. The Unit shall seek permission from CPCB, after compliance with the above mentioned directions before resumption of manufacturing operations.

**AND WHEREAS,** CPCB received adequacy assessment report vide letter dated 11.10.2017 from the Unit prepared by VSI, Pune; and

**WHEREAS,** CPCB issued direction dated 10.11.2017 under section 5 of Environment Protection Act, 1986 to the Unit to comply with the following directions;

1. The Unit shall start its operation with reduced capacity of 6500 TCD till the recommendation of the adequacy report are implemented.
2. The Unit shall start its operation only after obtaining valid consent from the concerned State Pollution Control Board.
3. The Unit shall submit implementation status of action plan before 30.11.2017.
4. The Unit shall install & Commission ETP system upto tertiary treatment level including adequate treatment system for spray pond overflow effluent in case of double sulphitation process (Brine recovery system to be installed in case of sugar refinery having Ion Exchange Process for sugar melt de-colorization).
5. The Unit having high pressure boiler (>45 Kg/cm<sup>2</sup>) shall install & Commission Condensate Polishing Unit (CPU) within 45 days for treatment of condensate water to ensure its reuse & recycle within the process.
6. The Unit shall implement the observation and recommendation of the adequacy report within 45 days.

**(Contd..3/-)**

7. The Unit shall restrict the effluent storage capacity to 15 days.
8. The Unit shall utilise treated effluent meeting the prescribed norms for irrigation as per the irrigation management plan validated by expert institutions namely, NSI, Kanpur/ VSI, Pune/ Agricultural Institutions.
9. The Unit shall get the verification of implement status of the recommendation of adequacy report including ETP performance assessment & effluent generation assessment done by the same institute which carried out adequacy assessment and submit the report to CPCB within 45 days from date of resumption of manufacturing operations.
10. The analysis result of the treated effluent shall also be submitted within 45 days through EPA recognised laboratories.
11. If the Unit fails to provide the verification report duly validated by the expert institutions, the Unit shall automatically stop all its manufacturing operations after 45 days from date of resumption of manufacturing operations.

**AND WHEREAS**, the Unit has submitted implementation status of recommendations of adequacy report vide letter dated 30.11.2017; and

**WHEREAS**, the Unit (M/s Doiwala Sugar Company Ltd., Doiwala, Dehradun, Uttarakhand) was inspected on 16.03.2018 by officials from CPCB and following observations are made;

1. The Unit and ETP were operational.
2. The Unit was operational without valid consent to operate. The Unit has applied for valid consent under Water (Prevention and Control of Pollution) Act, 1974 & Air (Prevention and Control of Pollution) Act, 1981.
3. The Unit has applied for NOC from Central Ground Water Authorisation (CGWA).
4. Effluent Treatment Plant (ETP) comprised of Bar Screen, Oil & grease trap, Equalisation Tank, Anaerobic Tank, Primary Clarifier, Aeration Tank, Secondary Clarifier and Sand Filter & Carbon Filter.
5. The analysis of treated effluent sample shows pH-7.33 as against norms of 5.5-9.0, **BOD-34 mg/l** against norms of 30 mg/l, COD- 91 mg/l against norms of 250 mg/l, **TSS- 49 mg/l** against norms of 30 mg/l and TDS- 860 mg/l against norms of 2100 mg/l which indicates non-compliance w.r.t. BOD & TSS against surface water discharge norms prescribed under Environment (Protection) Rules,1986.
6. MLSS in aeration tank was **878 mg/l** which indicates unstabilised Activated Sludge Process system due to poor operation and maintenance of ETP system and possibility of dilution of ETP system.
7. The Unit does not have separate provision for treatment of effluent from spray pond overflow.
8. Flow meters were installed at bore wells, inlet and outlet of ETP. However, flow meters were not installed at manufacture processes.

(Contd..4/-)

9. Treated effluent is discharged into a drain which ultimately meets the Song river.
10. Lagoon was under construction for storage of treated effluent in low demand period of irrigation.
11. The Unit has not submitted irrigation management plan.
12. The Unit has not submitted revalidated ETP adequacy assessment report within 45 days from the date of resumption of operation to CPCB.

**It is evident that the aeration tank of ETP system is not properly stabilised due to poor operation and maintenance of ETP system and there is possibility of dilution of ETP system. Untreated/ partially treated effluent is being discharged by the Unit, posing potential threat to surface water/ground water quality.**

**AND NOW, THEREFORE,** in view of above observation and in exercise of the powers delegated to the Chairman, CPCB under section 5 of the Environment (Protection) Act, 1986, notice is served herewith to **show cause why the Unit (M/s Doiwala Sugar Company Ltd., Doiwala, Dehradun, Uttarakhand) should not be closed down** until all the necessary pollution control measures are planned and implemented so as to comply with the directions dated 10-11-2017 and also to comply with the prescribed effluent discharge standards notified under Environment (protection) Act, 1986 to the satisfaction of CPCB and also **why appropriate environmental compensation not be imposed.**

You are hereby given an opportunity to file your objections (if any) to the above proposed direction within 15 days from the receipt of this notice, failing which appropriate action shall be taken against the Unit without giving any further notice, in accordance with provisions of the Environment (Protection) Act, 1986.

/

(S. P. SINGH PARIHAR)  
CHAIRMAN

**Copy to:**

**1. Member Secretary**

Uttarakhand Environment Protection & Pollution  
Control Board, 29/20, Nemi Road, Dehradun,  
Uttarakhand-248001

**2. Joint Secretary (CP Division)**

Ministry of Environment, Forest & C.C  
Prithvi Block, Indira Paryavaran Bhawan,  
Jorbagh Road, New Delhi – 110 003

:With request to ensure compliance  
of the directions.

:For kind information, please.

(Contd..5/-)

**3. District Magistrate**

Dehradun, U.P.

**4. Regional Director**

Regional Directorate

Central Pollution Control Board, PICUP Bhawan,

Ground Floor, Vibhuti Khand, Gomti Nagar,

Lucknow – 226 010

**5.** In-charge, IT Division, CPCB

**6.** Master file/Guard file, WQM II, CPCB Delhi

:For kind information, please.

:For follow up and ensuring compliance.



**(A SUDHAKAR)**

**MEMBER SECRETARY**