



B-29016/04/06/IPC-1/

SPEED POST

May 22, 2018

To

M/s. SVR Laboratories (P) Ltd.,  
Sy No. 239/A & 239/E, Dothigudem (V),  
Pochampally, Nalgonda-508284  
Telangana

**Sub.: Directions under Section 5 of the Environment (Protection) Act, 1986 regarding installation of on-line effluent and emission monitoring system-Show cause Notice**

WHEREAS, the Pharmaceutical industries are identified as one of the 17 categories of highly polluting industries which have been discharging environmental pollutants directly or indirectly into the ambient air and water, having potential threat to cause adverse effect on the water and air quality; and

WHEREAS, M/s. SVR Laboratories (P) Ltd., Telangana (herein after referred to as the Unit) which comes under pharmaceutical category, has installed online flow meter and web camera as the Online continuous effluent Monitoring system (OCEMS) as it is sending effluent to common effluent treatment plant (CETP); and

WHEREAS, it was observed by the IT division of the CPCB that the Online continuous effluent Monitoring system (OCEMS) of the Unit was in offline mode during the month of 15 February-15 March 2018; and


WHEREAS, the Unit was inspected by a team of official(s) from the CPCB Regional Directorate, Bangalore on April 24, 2018 to assess the adequacy of the existing pollution control measures and online effluent monitoring system, observed as following:


- i. The Unit is not segregating the HTDS & LTDS effluents and the Unit has not provided the separate collection tank of the storage of the LTDS effluent.
- ii. The Unit is not providing the proper camera coverage for outlet flow meter for HTDS and LTDS collection tanks.
- iii. The Unit is not adhering to the Telangana SPCB consent condition of regularly sending the HTDS & LTDS effluents to CETP.
- iv. The Unit is regularly using the stand by in-house ZLD facility to treat unsegregated effluents.
- v. The Unit is not providing the proper maintenance to in-house ZLD facility as the seals of the all feed pumps were worn and leakage of the effluent was observed.
- vi. The Unit is not maintaining the records of the disposal of effluent to CETP.
- vii. The housekeeping of the Unit is poor w.r.t storage of the solid residue/salt storage inside the ETP.

WHEREAS, the Ministry of Environment & Forests, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, a notice is hereby served to the Unit (M/s. SVR Laboratories (P) Ltd., Telangana) to show cause why the Unit should not be closed down as the Unit is not complying with respect to the above mentioned observations of the inspecting team.


The compliance of above direction (notice) shall be submitted to this office within 30 days of the receipt of the directions. In case of failure to comply with the said directions necessary action as deemed fit under the provision of the Environment (Protection) Act, 1986 will be taken by CPCB, which includes criminal prosecution of the Unit Head and levying penalty towards environmental compensation.

  
24/05/18  
(S. P. Singh Parihar)  
Chairman



Copy to:

1. The Chairman  
Telangana State Pollution Control Board  
Paryavaran Bhawan, A-3, Industrial  
Estate, Sanathnagar, Hyderabad-500018
2. The Advisor (CP Division)  
Ministry of Environment, Forests and Climate Change  
Prithvi Wing, 2nd Floor, Room No. 216, Indira  
Paryavaran Bhawan Aliganj, Jor Bagh Road, New Delhi - 110003
3. The Regional Directorate  
Central Pollution Control Board  
1st & 2nd Floors, Nisarga Bhavan, A-Block,  
Thimmaiah Main Road, 7th D Cross, Shivanagar, Opp.  
Pushpanjali Theatre, Bangalore -560 010
- ✓ 4. The Incharge, IT, CPCB
5. The Incharge, IPC-VI, CPCB

  
(A. Sudhakar)  
Member Secretary