

Speed Post

B-190198/NGRBA(RG)/CPCB/Distillery/6/2016-17/2979

June 20, 2018

25

To,

**M/s Wave Distilleries & Breweries Ltd., (Brewery unit)
Vill.-Ahmadpura, Ramghat Road,
Tehsil-Atrauli,
Distt.- Aligarh-202002 U.P.**

**SHOW CAUSE NOTICE UNDER SECTION 5 OF THE ENVIRONMENT
(PROTECTION) ACT, 1986**

WHEREAS, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act, 1986 and the rules framed there under; and

WHEREAS, the Ministry of Environment & Forests, Govt. of India, vide notification S.O.157(E) of 27.02.1996 has delegated powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board (CPCB), to issue direction to any industry, Municipal Corporation, Municipal Council, Cantonment Board to any local or other Authority for the violation of emission and effluent standards notified under the Environment (Protection) Rules, 1986; and

WHEREAS, it is obligatory on the part of industries to install effluent treatment plants (ETPs) to comply with the effluent discharge standards as notified under the Environment (Protection) Act, 1986 and the Rules framed there under and also to meet the consent conditions granted by State Pollution Control Board (SPCBs) / Pollution Control Committees (PCCs); and

WHEREAS, M/s. Wave Distilleries & Breweries Ltd., U.P (hereinafter referred as 'the Unit') is involved in the process of packed beer using broken rice as raw material ; and

WHEREAS, CPCB issued show cause notice to the unit dated 21.06.2016 for the installation of online effluent monitoring system w.r.t pH, BOD, COD, TSS ,COD and Flow meter in Distillery, Brewery & Malting Industries; and

WHEREAS, the unit was inspected by the officials of CPCB dated 08.02.2018 and following observations are made;

1. ETP consists of Anaerobic Process, Primary Treatment and Secondary clarifiers.
2. The unit is having consent validity up to 31.12.2019.
3. The unit has two bore wells for the extraction of ground water.

(Contd...2/-)

M/s Wave Distilleries & Breweries Ltd., (Brewery unit)

4. The unit has installed OCEMS online effluent monitoring system w.r.t. pH, BOD, TSS & COD.
5. The unit has installed flow meter at the inlet of ETP only; however no flow meter is installed at the ETP outlet.
6. Analysis result of ETP outlet showed high value of pH 8.14, BOD-44 mg/l as against norms of 30 mg/l, & TSS- 294 mg/l as against norms of 30 mg/l, COD 109 mg/l, & TDS 1384 mg/l .

AND WHEREAS, the unit (M/s, Wave Distilleries & Breweries Ltd.,) has not complied with the following;

1. The unit has not complied with the CPCB effluent discharged norms prescribed by Uttar Pradesh Pollution Control Board.
2. The unit has not installed flow meter at the outlet of ETP as per CPCB show cause notice dated 21.6.2016 issued under section 5 of E(P) Act,1986.

AND NOW, THEREFORE, in view of the above observations and exercising powers delegated to the Chairman, Central Pollution Control Board under Section 5 of the Environment (Protection) Act, 1986, notice is hereby served to the unit to **Show Cause why the Unit (M/s Wave Distilleries & Breweries Ltd.,) should not be closed down for not complying with the prescribed effluent discharge standards and non installation of flow meter at ETP and provide with its connectivity to CPCB server.**

The reply, if any to the Show Cause Notice shall be submitted to this office within 15 days from the date of receipt of this notice, failing which further necessary action will be taken without giving any further notice as per the provision of the Environment (Protection) Act 1986.

(S P Singh Parihar)
CHAIRMAN

Copy to:

1. Member Secretary
Uttar Pradesh Pollution Control Board,
Building No. TC-12V, Vibhuthi Khand,
Gomti Nagar, Lucknow – 226 010

With request to ensure that the unit complies with the directions.

2. Joint Secretary (CP Division)
Ministry of Environment, Forest & C.C
Prithvi Block, Indira Paryavaran Bhawan,
Jorbagh Road, New Delhi – 110 00

For Kind information,
please.

(Contd...3/-)

3. Regional Director

Regional Directorate
Central Pollution Control Board
PICUP Bhawan, Ground Floor,
Vibhuti Khand, Gomti Nagar,
Lucknow – 226 010.

: For follow up and ensuring
compliance

4. In-charge, IT Division, CPCB

5. Master file/Guard file WQM-II Division



(A. SUDHAKAR)

MEMBER SECRETARY

Sh. UAA. d
Sh. M. G. S. 2016