

BY REGD. AD

F. No. B-751(545)/Textile/WQM-II/CPCB/2017-18

Dated: 21.11.2017

To
M/s D. P. Yarn Dyers,
Village Babusarai, Maharajganj,
District Bhadohi, UP-221314

Directions under Section 5 of the Environment (Protection) Act, 1986 –reg.

WHEREAS, the Textile, Dyeing & Bleaching industries are identified as one of the Grossly Polluting industries (GPIs) which have been discharging environmental pollutants directly or indirectly into the ambient air and water, having potential threat to cause adverse effect on the water and air quality; and

WHEREAS, the Ministry of Environment & Forests, Government of India, vide Notifications No. S.O. 157 (E) of 27.02.1996 and S.O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof; and

WHEREAS, CPCB issued direction dated 16.05.2017 to the M/s D. P. Yarn Dyers, Village Babusarai, Maharajganj, District Bhadohi, UP-221314, (Herein after referred as the Unit) for compliance of following directions.

1. The unit shall close all the plant operations with immediate effect and shall not resume operations till the following are complied.
2. The unit shall install Zero Liquid Discharge (ZLD) system for effluent as per the condition given in the consent to operate under the Water Act, 1974 by the UPPCB vide dated May 18, 2016.
3. The unit shall obtain valid consent to operate under the Water Act, 1974 from UPPCB as the same has been cancelled due to non-compliance of consent condition.
4. The unit shall conduct component wise performance evaluation of ETP through NABL accredited and MoEF & CC recognized laboratory to explain high removal efficiency with compact ETP comprising of primary treatment only.
5. The unit shall obtain permission from CGWA for Groundwater extraction through bore wells.
6. The unit shall install flow meters at the bore wells, inlet and outlet of ETP and maintain log book for the water consumption, waste water generation.
7. The unit shall install and provide data connectivity of OCEMS in compliance of CPCB notice dated June 21, 2016.

AND WHEREAS, the Unit reply vide letter dated 13.09.2017 was examined and following observations made;

Contd...

1. The District Administration, Bhadohi closed the unit's operation on 23.08.2017 though the unit informed vide letter dated 31.08.2017 that it has stopped all wet operations with effect from 02.06.2017.
2. The unit has submitted Self-Certificate as per CPCB format.
3. The unit have valid consents under Air and Water Acts upto 31.12.2017
4. The unit has installed flow meters at the bore wells, inlet and outlet of ETP and maintain log book for the water consumption, waste water generation.
5. The unit has submitted details of registration and connectivity of the OCEMS with the CPCB portal and server.
6. The unit has installed ETP system of 150KLD design capacity, consisting of screen chamber, equalisation tank, primary tube settler, aeration tank (MBBR tank), secondary tube settler, multi grade filter, sludge drying bed and requested for revocation of closure for commission of ETP system.
7. The unit has submitted valid consent of Hazardous Waste Authorization.
8. The unit have applied for NOC to CGWA for groundwater abstraction.

AND WHEREAS, CPCB constituted a Three-member committee vide office order dated 27.09.2017 having representative from CPCB, MoEF & CC and NMCG for examination and recommendation for revocation of the closure direction issued by CPCB; and

WHEREAS, the Three-member committee in its meeting held on 15.11.2017 examined the reply dated 13.09.2017 and recommended for revoke of closure direction dated 16.05.2017.

NOW THEREFORE, in view of the above observations and in exercise of the powers delegated to the Chairman, Central Pollution Control Board under section 5 of the Environment (Protection) Act 1986, the closure direction dated 16.05.2017 is revoked and the unit M/s D. P. Yarn Dyers, Village Babusarai, Maharajganj, District Bhadohi UP-221314 is hereby directed to comply with the following directions;

1. The unit shall resume the manufacturing operation and informed immediately to CPCB; and
2. The Unit shall ensure all time compliance of the standards of treated effluent as per Gazette notification dated 10.10.2016 under Environment (Protection) Rules, 1986; and
3. The Unit shall submit the treated effluent analysis report by the laboratory recognized under the Environment (Protection) Act, 1986 within 30 days from the date of resumption of operation.

In case of failure of the unit to comply with the directions, action will be taken in accordance with the provisions under Environment (Protection) Act, 1986.


(S.P. SINGH PARIHAR)
CHAIRMAN

Copy to:

1. Member Secretary,
Uttar Pradesh Pollution Control Board,
Building No. TC-12V, Vibhuti Khand,
Gomti Nagar, Lucknow (UP) – 226 010
For necessary action
please
2. District Magistrate,
Collectorate, Bhadohi,
Distt- Bhadohi (U.P.)
For information please
3. The Advisor (CP Division)
Ministry of Environment, Forests & Climate Change
Prithvi Wing, 2nd Floor, Room No. 216 Indira
Paryavaran Bhawan Jor Bagh Road,
New Delhi – 110003
For information please
4. Managing Director
Bhadohi Electricity Supply Company Ltd.,
Bhadohi, UP
Reconnect the
electricity supply
5. Regional Directorate
Central Pollution Control Board.
PICUP Bhawan, Vibhuti Khand,
Gomti Nagar, Lucknow - 226 010
For information please
6. In-charge IPC-III Division, CPCB
For information please
- ✓ 7. In-charge IT Division, CPCB Delhi
For information please
8. In- charge WQM-II Division, CPCB Delhi
For information please



(A SUDHAKAR)
MEMBER CRETARY