



SPEED POST

F. No. B-751 (614)/Textile/WQM-II/CPCB/2017-18 114366 23.11.2017

To

M/s R.R. Dyers
Naya Bazar, Zahidpur Jayapur Bypass Road
Bhadohi, Uttar Pradesh 221401

DIRECTION UNDER SECTION 5 OF THE ENVIRONMENT (PROTECTION) ACT, 1986

WHEREAS, the Ministry of Environment & Forests, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof;

WHEREAS, the Textile, Dyeing & Bleaching industries have been identified as one the Grossly Polluting Industries (GPI) which have been discharging effluents directly or indirectly on land and into water, having potential threat to cause adverse effect on land and the ambient water quality; and

WHEREAS, the team of Officials from the Regional Directorate, Central Pollution Control Board (CPCB), Lucknow inspected M/s R.R. Dyers, Bhadohi- 221401, U.P. (herein after referred as the Unit) on March 22, 2017 to assess the adequacy of existing pollution control measures; and

WHEREAS, The analysis results of treated effluent sample collected from ETP outlet showed that Exceedance with respect to the prescribed standards with pH (7.62 > 6.5-8.5), TSS- (241 mg/l > 100 mg/l), COD - (194 mg/l < 250 mg/l), Colour- (100 Hazen < 150 mg/l), Ammonical Nitrogen (1.06 < 50 mg/l) and Sulphide- (7.39 mg/l > 2 mg/l), Phenol (1.59 mg/l > 1.0 mg/l), TDS (740 < 2100 mg/l) and SAR (2.13 < 20 mg/l); and

WHEREAS, it was observed that the unit has not obtained permission from CGWA for extraction of ground water from bore well, not installed water meter at bore well and not maintained the log book for water consumption; and

WHEREAS, it was observed that the Water and Air consent is valid till 31.12.2017 and consent for hazardous waste is valid till 28.12.2018; and

WHEREAS, CPCB issued dated 21.06.2016 notice under section 5 of the Environment (Protection) Act, 1986 was issued to the unit vide dated June 21, 2016 for installation and connectivity of On line Continuous Effluent Monitoring System OCEMS at final outlet of ETP; and

WHEREAS, CPCB issued direction dated 22.05.2017 under section 5 of Environment (Protection) Act, 1986 to the unit to comply with following

1. The unit M/s R.R. Dyers shall close all operations with immediate effect and shall not resume till the following are complied.
2. The unit shall upgrade and properly operate the effluent treatment plant so as to achieve the notified standards.
3. Unit shall obtain permission from CGWA for ground water extraction.

4. The unit shall install flow meters at the bore well inlet and outlet of ETP.
5. The unit shall maintain logbook for water consumption.
6. The unit shall install OCEMS for online monitoring for effluent and provide connectivity to CPCB server.

WHEREAS, the unit replies dated 26.09.2017, 28.09.2017 & 26.10.2017 were examined and following observations are made:

1. The unit has provided self certificate.
2. The unit has provided undertaking on Stamp paper.
3. The unit has valid consent under Air & Water Act with validity up to 31.12.2017.
4. Unit has installed OCEMS and is connected with CPCB server.
5. The unit has applied for NOC from CGWA. (copy provided).
6. The unit has provided snap shot of OCEMS and photographs of ETP.
7. The unit has valid consent for Hazardous waste authorization up to 28.12.2018
8. The unit has upgraded the ETP with blower and diffusers in the aeration tank to meet the treated effluent discharge norms and has provided the details.

WHEREAS, CPCB constituted a Three-member committee vide office order dated 27.09.2017 having representative from CPCB, MoEF &CC and NMCG for examination and recommendation for revocation of the closure direction issued by CPCB; and

AND WHEREAS, the three member committee in its meeting held on 15.11.2017 examined and recommended that the Unit may be allowed to resume operation.

NOW THEREFORE, in view of the above and in exercise of powers delegated under Section 5 of the Environment (Protection) Act, 1986, to the Chairman, Central Pollution Control Board (CPCB) the direction issued to the unit dated 22.05.2017 is hereby revoked and the unit is directed to comply with following directions:

1. The Unit, M/s R.R. Dyers, Bhadohi- 221401, U.P shall resume operation and shall inform to CPCB immediately.
2. The unit shall ensure to provide continuous data for online effluent monitoring system (OCEMS) to CPCB server.
3. The unit shall operate ETP so as to meet the stipulated standards notified under Environment (Protection) Act, 1986 and provide treated effluent analysis report within 30 days from the resumption of operation by EPA, 1986 recognized lab to CPCB.

In case of default in compliance with the above directions CPCB will be constrained to initiate appropriate actions against the unit, without giving any further notice, in accordance with provisions of Environment (Protection) Act, 1986.



24.11.2017
(S. P. SINGH PARIHAR)
CHAIRMAN



Copy to:

1. **Chairman,** : [For kind information
Uttar Pradesh Pollution Control Board
Building No. TC-12V, Vibhuti Khand,
Gomati Nagar, Lucknow
2. **The Advisor** (CP Division). : [For kind information]
Ministry of Environment, Forests & Climate
Change, Indra Paryavaran Bhavan,
Jor Bagh Road, New Delhi - 110 003
3. **District Magistrate** : For kind information
Distt- Bhadohi, U.P.
4. **The Regional Director,** : [For kind information]
Northern Regional Office,
Central Pollution Control Board,
PICUP Bhawan, Vibhuti Khand,
Gomati Nagar, Lucknow
5. **Managing Director** [For information & necessary action
Purvanchal Vidyut Vitran Nigam Ltd. please]
DLW, Bhikaripur, Varanasi - 221004
6. The Incharge IT Division, CPCB, Delhi : [To place the direction on CPCB
portal]
7. Master copy, WQM-II Division, CPCB, Delhi



(A.SUDHAKAR)
MEMBER SECRETARY