

o/c.

By Speed Post

F. No. B-190193/NGRBA(RG)/CPCB/P&P/49/2016-17 15376 29 December, 2017

To

**M/s Naini Tissues Ltd.,
7th Km. Stone, Moradabad Road
Kashipur (Udham Singh Nagar)
Uttarakhand**

DIRECTION UNDER SECTION 5 OF THE ENVIRONMENT (PROTECTION) ACT, 1986

WHEREAS, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act, 1986 and the rules framed there under; and

WHEREAS, the Ministry of Environment, Forest and Climate Change, Govt. of India, vide notification S.O.157(E) of 27.02.1996 has delegated powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board (CPCB), to issue direction to any industry, Municipal Corporation, Municipal Council, Cantonment Board to any local or other Authority for the violation of emission and effluent standards notified under the Environment (Protection) Rules, 1986 and other standards and norms; and

WHEREAS, M/s Naini Tissues Ltd., 7th Km. Stone, Moradabad Road Kashipur (Udham Singh Nagar) Uttarakhand (hereinafter referred as 'the Unit') is engaged in the production of writing and printing grade paper at an installed capacity of 140 Tonnes/ day ; and

WHEREAS, CPCB issued direction under section 18 (1) (b) of the Water/ Air Acts on February 24, 2015 to Uttarakhand Environmental protection and Pollution Control Board (UEPPCB) for implementation of the '*Charter for water recycling & pollution prevention in pulp & paper industries*'; and

WHEREAS, Uttarakhand Environment Protection and Pollution Control Board (UEPPCB) issued direction under section 33 (A) of the Water Act, 1974 to the Unit on 13.03.2015 for implementation of the '*Charter for water recycling & pollution prevention in pulp & paper industries*' (herein after referred to as 'the charter');

WHEREAS, the unit was inspected by the officials of CPCB on 09.11.2017 and made the following observations:

1. The unit and ETP both found operational at the time of inspection.
2. The unit has consent to operate under Water and Air Act, valid upto 31.03.2018.
3. The unit has valid authorization under Hazardous and other waste Rule upto 31.03.2018.


Cont....2/-

4. The unit is agro-based with consented capacity of 4200 MT/Month for production of Writing and printing paper.
5. The unit consumes fresh water about 5070 KLD on an average and waste water discharges about 3043 KLD.
6. The OCEMS is installed and connected with CPCB server.
7. The Effluent treatment plant includes pre equalization/mixing tank, equalization tank, primary clarifier, aeration tank. Secondary clarifier, tertiary clarifier and dual media filter.
8. Unit has installed Bio-Methanation Plant and Chemical Recovery Plant (CRP).
9. The ETP is upgraded up to tertiary level.
10. The treated effluent is discharged in Dhandi nallah from where it goes to Dehla river and meets to river ram ganga.
11. The analysis report of treated effluent sample showed TSS- 55.0 mg/l (as against 50mg/l), COD- 64 mg/l (as against 250 mg/l) and BOD- 09 mg/l (as against 30 mg/l) which indicates **non-compliance of prescribed norms with respect to TSS.**

AND NOW, THEREFORE, in view of the above observations and in exercise of the powers, delegated to the Chairman, CPCB under section 5 of the Environment (Protection) Act, 1986, Unit M/s Naini Tissues Ltd., 7th Km. Stone, Moradabad Road Kashipur is directed to comply with following direction:

1. Unit shall streamline the operations of ETP so as to ensure the treated effluent comply with prescribed effluent discharge norms.
2. The unit shall make stack monitoring facility as per the ERP-III norms for all the stacks attached with boilers. The port hole and ladder facility must be safe to carry out the monitoring.

In case of default in compliance with the above directions CPCB will be constrained to initiate appropriate action against the unit, without giving any further notice, in accordance with provisions of Environment (Protection) Act, 1986.


(S.P. SINGH PARIHAR)
CHAIRMAN
29.12.17

Copy to:

1. **The Member Secretary**
Uttarakhand Environment Protection &
Pollution Control Board,
29/20 Nemi Road Dehradun
Uttarakhand-248001

: With request to ensure the availability of stack monitoring facility prior to issuing the consent.

Cont.....3/-

e/c


Arjasthi

2. **The Incharge, Zonal Office** : [For kind information]
Central Pollution Control Board,
PICUP Bhawan, Ground Floor
Vibhuti Khand, Gomati Nagar,
Lucknow-226010

3. **The Advisor (CP Division)** : [For kind information]
Ministry of Environment, Forests & Climate Change,
Indra Paryavaran Bhavan,
Jor Bagh Road, New Delhi - 110 003

✓ 4. The Incharge, IT Division, CPCB : [For uploading on CPCBs website]

5. Master copy RG, CPCB



(A. SUDHAKAR)

MEMBER SECRETARY

o/c