



etc

केन्द्रीय प्रदूषण नियंत्रण बोर्ड
CENTRAL POLLUTION CONTROL BOARD
पर्यावरण, वन एवं जलवायु परिवर्तन मंत्रालय भारत सरकार
MINISTRY OF ENVIRONMENT, FOREST & CLIMATE CHANGE GOVT. OF INDIA

By Speed post

F. No. B- 190193/Pulp & Paper/WQM-II/CPCB/2017-18

November 29, 2018

To,

**M/s Devrishi Papers (P) Ltd.,
Jaspur- Kashipur Road,
Jagatpur Patti, Jaspur-244712,
Uttarakhand**

DIRECTION UNDER SECTION 5 OF THE ENVIRONMENT (PROTECTION) ACT, 1986

WHEREAS, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act, 1986 and the rules framed there under; and

WHEREAS, it is obligatory on the part of industries to install effluent treatment plants (ETPs) to comply with the effluent discharged standards as notified under the Environment (Protection) Act, 1986 and the rules framed there under and also to meet the consent conditions granted by State Pollution Control Board (SPCBs)/ Pollution Control Committees (PCCs); and

WHEREAS, the Ministry of Environment & Forests, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of emission and effluent standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof; and

WHEREAS, M/s Devrishi Papers (P) Ltd., Jaspur- Kashipur Road, Jagatpur Patti, Jaspur-44712, Uttarakhand, (hereafter referred to as the 'Unit') is a waste paper based mill producing semi kraft paper with installed production capacity of 150 TPD; and

WHEREAS, the Unit was inspected by the officials of CPCB on June, 6, 2016 and following observations are made:

1. During inspection, the unit is running at a production capacity of 50 TPD and its ETP was operational.
2. The unit has installed 'V' notch for flow measurement at the inlet and outlet of ETP.
3. The unit has installed online effluent monitoring system and connected to CPCB server.
4. The analysis of ETP outlet sample showed TSS-48 mg/l (charter norms-30 mg/l), BOD- 41 mg/l (Charter norms of 20 mg/l) and COD-256 mg/l (Charter norms-150 mg/l), indicating non-compliance with the effluent discharged quality norms as prescribed under the charter.
5. The partially treated effluent from ETP is being discharged into the adjacent drain which ultimately meets river Dhela.

AND WHEREAS, the Unit was issued Show Cause Direction under Section 5 of the Environment (Protection) Act, 1986, on dated 17-08-2016.

AND WHEREAS, the Unit vide letter dt.19-09-2016 & 16-10-2018 submitted compliance report to CPCB and were examined; and

Cont.....2

'परिवेश भवन' पूर्वी अर्जुन नगर, दिल्ली-110032

Parivesh Bhawan, East Arjun Nagar, Delhi-110032

दूरभाष/Tel : 43102030, 22305792, वेबसाईट/Website : www.cpcb.nic.in

WHEREAS, the Unit was inspected by the third party technical institutions on 23-04-2018 and observed following:

1. The Unit and ETP was found operational at the time of visit.
2. The mill has average fresh water consumption 9.3 m³/t of paper and waste water discharge about 6.1 m³/t of paper produced.
3. As per the design specification the ETP units appears to be adequate to treat the effluent to meet the prescribed norms.
4. The results of analysis of the collected samples indicated that the mill is achieving the stipulated norms.
5. Flow meter are available at bore well to monitor the fresh water consumption on regular basis
6. Multi Cyclone and Wet scrubber are available at the boiler for control of particulate matter.
7. Variation has been observed in the results of the analysis of final discharge w.r.t to OCEMS reading at time of sample collection.
8. The down stream sample analysis results indicate further dilution of pollution load.
9. The analysis of ETP outlet sample showed pH 7.3(as against of 5.5-8.5), TSS-48 mg/l (as against of 50 mg/l), BOD- 10 mg/l (as against 30mg/l) and COD-130 mg/l (as against 250 mg/l), which indicates compliance with the stipulated norms by CPCB.

AND NOW, THEREFORE, in view of the above observations and in exercise of the powers, delegated to the Chairman, CPCB under section 5 of the Environment (Protection) Act, 1986, the unit *M/s Devrishi Papers (P) Ltd.*, Jaspur- Kashipur Road, Jagatpur Patti, Jaspur-44712,Uttarakhand, is hereby directed to comply with following directions:

1. The unit shall provide ETP treated effluent sample analysis report prepared by any EPA recognised lab with in 45 days to CPCB.
2. The unit shall maintain the complying status and if found non complying at any stage closure direction will be issued without further notice.
3. The unit shall ensure to provide Online Continuous Effluent Monitoring System (OCEMS) data continuously on CPCB server.

In case of default in compliance with the above directions CPCB will be constrained to initiate appropriate actions against the unit, without giving any further notice, in accordance with provisions of Environment (Protection) Act, 1986.


(S.P. SINGH PARIHAR)
CHAIRMAN

To:

1. The Member Secretary

Uttarakhand Environment Protection
& Pollution Control Board
29/20 Nemi Road Dehradun
Uttarakhand-248001


[For kind information]

2. **The Joint Secretary (CP Division).**
Indra Paryavaran Bhavan,
Ministry of Environment, Forests & Climate Change,
Jor Bagh Road, New Delhi - 110 003
3. **The Regional Director,**
Regional Directorate (N),
Central Pollution Control Board,
Zonal Office (North) PICUP
BhawanVibhuti Khand, Gomti Nagar,
Lucknow - 226 010, Uttar Pradesh
4. The Incharge, IT Division, CPCB
5. Master copy WQM-II, CPCB

For information please

For information please

For uploading on CPCBs website



(PRASHANT GARGAVA)
MEMBER SECRETARY

etc

