



SPEED POST

B-29016/04/06/IPC-1/654

July 25, 2018

To

M/s Novateur Electrical Digital System Pvt. Ltd.,
51 KM G.T. Karnal Road-Murthal,
Dist. Sonapat
Haryana- 131027

Sub.: Directions under Section 5 of the Environment (Protection) Act, 1986 -Show cause Notice

WHEREAS, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act, 1986 and the rules framed thereunder; and

WHEREAS, it is obligatory on the part of industries to install and operate Effluent Treatment plant (ETP) to comply with the effluent discharge standards as notified under the Environment (Protection) Act, 1986 and the Rules framed thereunder and also to meet the consent conditions granted by State Pollution Control Board (SPCB)/ Pollution Control Committees (PCCs); and

WHEREAS, Hon'ble Supreme Court of India in the matter of Paryavaran Suraksha Samiti Vs Union of India & Others dated 22/02/2017 directed that no industry which requires "consent to operate" from the concerned Pollution Control Board, is permitted to function, unless it has a functional effluent treatment plant, which is capable to meet the prescribed norms for removing the pollutants from the effluent, before it is discharged; and

WHEREAS, a team of officers from the Central Pollution Control Board (CPCB), Delhi inspected M/s Novateur Electrical Digital System Pvt. Ltd., 51 KM G.T. Karnal Road-Murthal, Dist. Sonapat, Haryana (herein after referred as the Unit) on May 16, 2018 to assess the adequacy of the existing pollution control measures; and

WHEREAS, the inspecting team found the Unit was operational and observed the following:

1. The unit has been using treated effluent inside the premises for gardening and disposal at land.
2. As per analysis report of samples collected from ETP outlet, the treated effluent is exceeding the prescribed limit of the parameters Nickel (3.48 mg/l > 3 mg/l) and Cyanides (0.24 mg/l > 0.20 mg/l) for electroplating industries.

WHEREAS, the Ministry of Environment & Forests, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, a notice is hereby served to the Unit (M/s Novateur Electrical Digital System Pvt. Ltd., 51 KM G.T. Karnal Road-Murthal, Dist. Sonapat, Haryana) to show cause as to why the Unit should not be closed down till following directions are complied:

1. The Unit shall operate Effluent Treatment Plant properly so as to achieve prescribed standards for effluent discharge.


The compliance of above direction (notice) shall be submitted to this office within 30 days of the receipt of the directions. In case of failure to comply with the said directions necessary action as deemed fit under the provision of the Environment (Protection) Act, 1986 will be taken by CPCB, which includes criminal prosecution of the Unit Head and levying penalty towards environmental compensation.



(S. P. Singh Parihar)
Chairman


Copy to:

1. The Chairman
Haryana State Pollution Control Board
C-11, Sector - 6
Panchkula,
Haryana-134109
2. The Advisor (CP Division)
Ministry of Environment, Forests and Climate Change
Prithvi Wing, 2nd Floor, Room No. 216
Indira Paryavaran Bhawan
Aliganj, Jor Bagh Road
New Delhi - 110003
3. The Incharge, Regional Directorate
Central Pollution Control Board
Ground & First Floor, PICUP Bhawan
Vibhuti Khand, Gomti Nagar
Lucknow - 226 020



27/7/14

4. ✓ I/c, IT Division, CPCB



(Prashant Gargava)
Member Secretary

O/C