



केन्द्रीय प्रदूषण नियंत्रण बोर्ड
CENTRAL POLLUTION CONTROL BOARD
पर्यावरण, वन एवं जलवायु परिवर्तन मंत्रालय भारत सरकार
MINISTRY OF ENVIRONMENT, FOREST & CLIMATE CHANGE GOVT. OF INDIA
BY REGISTERED AD

B-29016/04/06/IPC-I/ 742

August 08, 2018

To

M/s. Inmax Foods Pvt. Ltd.,
Plot No. 11, 12, HSIIDC, Murthal,
Sonipat- 131001, Haryana

Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 -reg.

WHEREAS, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act, 1986 and the rules framed thereunder; and

WHEREAS, it is obligatory on the part of industries to install and operate Effluent Treatment plant (ETP) to comply with the effluent discharge standards as notified under the Environment (Protection) Act, 1986 and the Rules framed thereunder and also to meet the consent conditions granted by State Pollution Control Board (SPCB)/ Pollution Control Committees (PCCs); and

WHEREAS, Hon'ble Supreme Court of India in the matter of Paryavaran Suraksha Samiti Vs Union of India & Others dated 22/02/2017 directed that no industry which requires "consent to operate" from the concerned Pollution Control Board, is permitted to function, unless it has a functional effluent treatment plant, which is capable to meet the prescribed norms for removing the pollutants from the effluent, before it is discharged; and

WHEREAS, a team of officers from the Central Pollution Control Board (CPCB), Delhi inspected M/s. Inmax Foods Pvt. Ltd., Sonipat (herein after referred as the Unit) on May 22, 2018 to assess the adequacy of the existing pollution control measures; and

WHEREAS, the inspecting team found the Unit was operational and observed the following:

1. The ETP of the Unit was found non-operational during visit and treatment units were found in defunct condition.
2. Discharged effluent exceeding the prescribed limit w.r.t parameters pH (5.13 < 5.5-9.0), TSS (619 > 200 mg/l), BOD (2282 > 100 mg/l), COD (4527 mg/l), Sulphates (161 mg/l).
3. The unit has not provided the flow meter at the ETP and records for treated waste water are not maintained.
4. The unit has not provided the dedicated area for storage of sludge.
5. The unit has not installed the flow meter on the bore well for ground water extraction and records are not maintained for daily water consumption.

WHEREAS, the Ministry of Environment & Forests, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

NOW, THEREFORE, in exercise of powers vested under Section 5 of the Environment (Protection) Act, 1986, the following directions are being issued:

1. The Unit shall close all the plant operations with immediate effect.
2. The Unit shall operate Effluent Treatment Plant properly so as to achieve prescribed standards for effluent discharge.
3. The Unit shall not discharge untreated effluent to the environment.
4. The Unit shall install the flow meter at the ETP and Bore Well and maintain the log book for consumption of water and waste water treatment.
5. The Unit shall handle ETP sludge as per Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016.
6. The Unit shall not resume the operation till the compliance of above directions and permission is obtained from the CPCB for the same.

In case of failure to comply with the said directions necessary action as deemed fit under the provision of the Environment (Protection) Act, 1986 will be taken by Central Pollution Control Board.

✓

13.8.18

(S.P. Singh Parihar)

Chairman

[Signature]

Copy to:

1. The Chairman
Haryana State Pollution Control Board
C-11, Sector - 6, Panchkula, Haryana
2. The Advisor (CP Division)
Ministry of Environment, Forests and Climate Change
Prithvi Wing, 2nd Floor, Room No. 216
Indira Paryavaran Bhawan
Aliganj, Jor Bagh Road New Delhi - 110003
3. The Managing Director,
Uttar Haryana Bijli Vitran Nigam Ltd. : With request to disconnect
(UHBVNL) Vidyut Sadan, industrial Electricity supply of
Plot No: C16, Sector-6, the Unit, allowing the supply
Panchkula, Haryana only for domestic & security
purposes.
4. The Incharge, Regional Directorate
Central Pollution Control Board
Ground & First Floor, PICUP Bhawan
Vibhuti Khand, Gomti Nagar
Lucknow - 226 020
5. ✓ I/c, IT, CPCB

[Signature]

(Prashant Gargava)
Member Secretary