



By registered AD

File No. B-190194/Textile/New/WQM-II/CPCB/2017-18

26-09-2018
01-10-2018

To,

M/s. M.K. Dyeing,
Site-3, Panki, Kanpur, UP

Directions under Section 5 of the Environment (Protection) Act, 1986

WHEREAS, the Textile, Dyeing & Bleaching industries are identified as one of the 17 categories of highly polluting industries which have been discharging effluent directly or indirectly into the ambient air and water, having potential threat to cause adverse effect on the water and air quality; and

WHEREAS, the Ministry of Environment, Forests and Climate Change, Government of India, vide Notifications No. S.O. 157 (E) of 27.02.1996 and S.O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof; and

WHEREAS, the unit M/s. M.K. Dyeing, Site-3, Panki, Kanpur, UP (hereafter referred to as the 'Unit') was inspected by a team from CPCB on 05.04.2018 for verification of compliance status and found that the unit is not complying with stipulated effluent discharge norms; and

WHEREAS, CPCB issued show cause notice under section 5 of the Environment (Protection) Act, 1986 on dated 04/06.06.2018; and

WHEREAS, the unit reply vide letter dated 28.06.2018 was examined; and

WHEREAS, the unit was jointly inspected by CPCB and UPPCB team on 10.08.2018 for verification of compliance status and following observation are made:

1. The unit was found operational during the inspection.
2. ETP of the unit was found operational at the time of inspection.
3. The unit produces Dyed Hosiery Cloths with a valid consent of dyeing hosiery cloths 250 kg/day.
4. The unit has valid consent to operate with validity upto 31.12.2019.
5. The unit has applied for renewal of hazardous waste authorization and applied for NOC of CGWA for ground water extraction.
6. The treated water from the Unit is discharged into Pandu River at a distance of 01 KM from the unit.
7. The OCEMS system of the Unit was found installed and connected with CPCB server.
8. The characteristics of effluent based on samples collected from ETP outlet during inspection on 10.08.2018 was found as follows: pH - 7.84 against standards of 6.5-8.5; Suspended Solid - 3.33 mg/l against a standard of 100 mg/l; Color - 20 against a standard of 150; BOD - 5.24 mg/l against a standard of 30 mg/l; Oil & Grease < 5 mg/l against standard of 10 mg/l; COD - 52.1 mg/l against standards of 250 mg/l; Total Cr<0.2 mg/l against standards of 2.0 mg/l; Sulphide - <1 mg/l

M/s. M.K. Dyeing, Site-3, Panki, Kanpur, UP

against standard of 2.0 mg/l; Phenols against 0.32 mg/l against standard of 1.0 mg/l; TDS - 2058 against a standard of 2100 mg/l; and Ammonia - 0.928 mg/l against a standard of 50 mg/l.

9. Treated effluent analysis report revealed that the unit was found complying w.r.t. effluent discharge standards at the time of inspection.
10. The unit was found maintaining the logbook for flowmeter at the ETP outlet, chemical consumption and production.

AND NOW THEREFORE, in view of the above and in exercise of the powers, delegated to the Chairman, CPCB under Section 5 of the Environment (Protection) Act, 1986, the unit namely **M/s. M.K. Dyeing, Site-3, Panki, Kanpur, UP** is directed to comply with the following directions:


1. The Unit shall operate ETP properly so as to ensure compliance with the effluent discharge norms notified under Environment (Protection) Act, 1986.
2. The Unit shall ensure continuous connectivity OCEMS with CPCB server.

In case of default in compliance with the above directions CPCB will be constrained to initiate appropriate actions against the unit, without giving any further notice, in accordance with provisions of Environment (Protection) Act, 1986.


(ARUN KUMAR MEHTA)
CHAIRMAN

Copy to:

- o/c
- 1 **Member Secretary**
Uttar Pradesh Pollution Control Board
Building No-TC- 12 V, Vibhuti Khand,
Gomati Nagar, Lucknow-226010 : [To ensure compliance of
the direction please]
 - 2 **Joint Secretary (CP Division)**
Ministry of Environment, Forests & Climate Change, Indira : [For kind information
Paryavaran Bhavan, Jor Bagh Road, New Delhi - 110 003 please]
 - 3 **District Magistrate**
Collectorate Office, District; Kanpur : [For kind information
Uttar Pradesh-208022 please]
 - 4 **Regional Director,**
Regional directorate,
Central Pollution Control Board, : [For information]
Ground Floor, PICUP Bhawan, Vibhuti Khand, Gomti Nagar,
Lucknow-226010 (U.P.)
 - 6 ✓ The Incharge IT Division, CPCB, Delhi : [For uploading the direction
at CPCB website]
 - 7 The Incharge WQM-II, CPCB, Delhi : [For kind information please]


(PRASHANT GARGAVA)
MEMBER SECRETARY

o/c

Page 1 of 2

Agasthi