

**Speed Post**

F.No. B-457(T)/IPC-III/2019-20/ 1345

April 23, 2019

To,

**M/s RBT Private Limited,  
Khasara No 48/21, 47125 Yillage Dhatir,  
District-Palwal (Haryana)**

**DIRECION UNDER SECTION 5 OF THE ENVIRONMENT (PROTECTION) ACT, 1986**

**WHEREAS**, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act,1986 and the rules framed there under; and

**WHEREAS**, the Ministry of Environment & Forests, Govt. of India, vide notification S.O.157(E) of 27.02.1996 has delegated powers vested under Section 5 of the Environment (Protection) Act,1986 (29 of 1986) to the Chairman, Central Pollution Control Board (CPCB), to issue direction to any industry, Municipal Corporation, Municipal Council, Cantonment Board to any local or other Authority for the violation of emission and effluent standards notified under the Environment (Protection) Rules,1986; and

**WHEREAS**, it is obligatory on the part of industries to install effluent treatment plants (ETPs) to comply with the effluent discharge standards as notified under the Environment (Protection) Act, 1986 and the Rules framed thereunder and also to meet the consent conditions granted by State Pollution Control Board (SPCBs) / Pollution Control Committees (PCCs); and

**WHEREAS**, the inspection of **M/s RBT Private Limited, Khasara No 48/21, 47125 Yillage Dhatir, District-Palwal (Haryana) (hereinafter referred as 'the Unit')** was carried out on 15.03.2019 by the team from CPCB, Regional Directorate, Lucknow under OCEMS surveillance programme. The unit was engaged in grey fabrics to finished fabrics through Bleaching, Dyeing and drying process. Following major observations were made by the team during the visit:

1. The unit has installed processing capacity of 5 TPD for dyeing. The unit was reportedly operating at 3 TPD capacity, at the time of inspection.
2. During inspection, the unit and its ETP were found operational.
3. The unit has not obtained permission from Central Ground Water Authority (CGWA) for extraction of the ground water.
4. All sludge drying beds were found full during inspection.
5. The unit has not installed a separate energy meter for ETP.
6. The unit has not engaged skilled manpower for operation& maintenance of ETP.
7. The unit has not provided adequate chemical dosing system at ETP.
8. It was observed that raw effluent carrying channel of ETP was choked and stagnant effluent was there at ETP.
9. It was observed that ETP sludge and empty chemical drums were kept in open area.

10. Grab samples were collected from inlet and outlet of ETP. The analysis results are given in table below:

Sampling locations	Parameters				
	pH	O&G	TSS (mg/l)	BOD (mg/l)	COD (mg/l)
Inlet of ETP	8.82	-	377	371	939
Outlet of ETP	8.07	7.66	111	83.5	202
<b>Standards</b>	<b>6.5-9.0</b>	<b>10</b>	<b>100</b>	<b>30</b>	<b>250</b>

It is evident that the outlet sample analysis results are higher than the prescribed discharge standards w.r.t. **BOD& TSS**.

11. The unit discharges its ETP treated effluent to adjacent Gauchi drain which ultimately meets River Yamuna.

**NOW, THEREFORE**, in view of the above, and exercising the powers delegated to the Chairman, Central Pollution Control Board (CPCB) under section 5 of the Environment (Protection) Act, 1986, **notice is served herewith to show cause why M/s RBT Private Limited, Khasara No 48/21, 47125 Yillage Dhatir, District-Palwal (Haryana)** should not be closed down till it complies with the following directions:

1. The unit should ensure operation & maintenance of the ETP so that to achieve the prescribed norms and submit sample analysis report from E (P) A approved laboratory.
2. The unit shall carry out adequacy assessment of ETP through reputed organisation/institute preferably IIT/NIT/NEERI & accordingly upgrade its ETP so as to meet the prescribed discharge standards by HSPCB.
3. The unit should obtain permission from Central Ground Water Authority (CGWA) for extraction of the ground water.
4. The unit shall engage skilled manpower for operation& maintenance of the ETP.
5. The unit shall install a separate energy meter for ETP and maintain records of the same.
6. The unit shall provide storage shed for ETP sludge and empty chemical containers as Per HWM& TBM Rule, 2016.
7. The unit shall install Electromagnetic flow meters in place of Mechanical type water meter at all water abstraction points.
8. The unit shall provide pressure gauge at filtration system for measuring pressure head.

You are hereby given an opportunity to file your objections (if any) to the above proposed notice within 15 days from the receipt of this notice, failing which it will be presumed that you have nothing to say and appropriate action, in accordance with the provisions of the Environment (Protection) Act, 1986, will be taken against the Unit without giving any further notice.

(S. P. SINGH PARIHAR)  
CHAIRMAN

Copy to:

- 1) **The Member Secretary,**  
Haryana State Pollution Control Board,  
C-11, Sector 6, Panchkula,  
**Haryana-134109** : For ensuring compliance of  
directions please.
- 2) **The Regional Director,**  
CPCB Regional Directorate,  
PICUP Bhawan,  
Ground Floor, Vibhuti Khand, Gomti Nagar,  
**Lucknow-226 010** : For follow up and ensuring  
compliance of the directions, please.
- 3) **The Director, (CP Division),**  
Ministry of Environment, Forests & CC,  
Prithvi Block, Indira Paryavaran Bhawan,  
Jorbagh Road, **New Delhi - 110 003** : For information, pl.
- 4) ✓ The Div. Head, IT Division, CPCB Delhi : For uploading the direction in CPCBs  
website please
- 5) The Div. Head, IPC-VI, Division, CPCB Delhi : For information, pl.
- 6) The Div. Head, IPC-III Division, CPCB Delhi : For records purpose.



**(A SUDHAKAR)**  
**MEMBER SECRETARY**