

SPEED POST

F. No. B-190194/WQM-II/Others/WQM-II/CPCB/2017-18

8438

23 August, 2017

To

**M/s N. K. Laminates (P) Ltd.
Vill- Dedupur, Post- Sambhalpur
Shivrajpur, Kanpur
Uttar Pradesh**

DIRECTION UNDER SECTION 5 OF THE ENVIRONMENT (PROTECTION) ACT, 1986

WHEREAS, the Ministry of Environment & Forests, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof; and

WHEREAS, M/s N. K. Laminates (P) Ltd., Vill- Dedupur, Post- Sambhalpur, Kanpur, Uttar Pradesh (hereafter referred to as the 'Unit') is a polluting industry engaged in processing of Kutch & Kattha with consented capacity of 180Kg/day : and

WHEREAS, the unit had informed that their unit fall under SSI and is engaged in Kattha and Cutch manufacturing. The water discharge of the unit is less than 03 KL and unit is not in the list of grossly polluting industries (GPIs) issued by UPPCB.

WHEREAS, CPCB issued revoke direction dated 25.07.2016 to exempt the unit from installation of the OCEMS; and

WHEREAS, the unit was jointly inspected on 23rd May, 2017 by the officials of CPCB to verify the implementation of action plan for water conservation & zero liquid discharge and made following observations:

1. The unit is engaged in manufacturing of Kattha/ Cutch from Khair wood/ cashew husk.
2. The waste water is generated mainly from filter cloth washing, floor washing, and boiler blow down.
3. The unit has valid consent under Water Act 1974 as well as Air Act 1981 and is valid up to December 12, 2019.
4. The unit has not provided electromagnetic flow meter at inlet of bore well and outlet of ETP. No record for water consumption was maintained.
5. The unit has not obtained Authorization under Hazardous waste management & handling Rules for storage of Hazardous waste generated from ETP.
6. The unit has installed ETP consisting of Equalization tank, Chemical mixing tank PST, Aeration Tank, SST, Carbon Filter.
7. The ETP treated effluent is used for irrigation of in campus cultivation.
8. The ETP treated effluent analysis report shows: BOD- 35.7 (as against norms of 30.mg/l); COD 130 mg/l (as against norms of 250 mg/l); TSS -86.3 (as against norms of 200 mg/l for land disposal).

AND NOW, THEREFORE, in view of the above observations and in exercise of the powers,

Cont.....

'परिवेश भवन' पूर्वी अर्जुन नगर, दिल्ली-110032
Parivesh Bhawan, East Arjun Nagar, Delhi-110032

दूरभाष: 31-43102030, 22305792, फेक्स: 31-43102030, वेबसाइट: www.cpcb.nic.in

delegated to the Chairman, CPCB under section 5 of the Environment (Protection) Act, 1986, notice is hereby served to the Unit to show cause, why the Unit M/s **N. K. Laminates (P) Ltd. Vill-Dedupur, Post- Sambhalpur**, Kanpur, Uttar Pradesh, **should not be closed** until the compliance of following direction:

1. The unit shall maintain the treatment plant so as to meet the effluent discharge norms as per the provision of Environment (Protection) Act, 1986.
2. The unit shall maintain the ZLD condition as per the consent issued by UPPCB.

You are hereby given an opportunity to file your objections (if any) to the above proposed directions within 15 days from the receipt of this notice, failing which appropriate action will be taken against the Unit, without giving any further notice, in accordance with provisions of the Environment (Protection) Act, 1986.


(S.P. SINGH PARIHAR)
CHAIRMAN

23/08/2017

Copy to:

1. **The Member Secretary**
Uttar Pradesh Pollution Control Board
Building No. TC-12V, Vibhuti Khand,
Gomati Nagar, Lucknow : [For kind information]
2. **The Incharge, Zonal Office**
Central Pollution Control Board,
PICUP Bhawan, Ground Floor
Vibhuti Khand, Gomati Nagar,
Lucknow-226010 : [For kind information]
3. **The Advisor (CP Division)**
Ministry of Environment, Forests & Climate Change,
Indra Paryavaran Bhavan,
Jor Bagh Road, New Delhi - 110 003 : [For kind information]
- ✓ 4. **The Incharge, IT Division, CPCB** : [For uploading on CPCBs website]
5. Master copy WQM-II, CPCB


(A.B. AKOLKAR)
MEMBER SECRETARY

Agarwal