



23/07/19

केन्द्रीय प्रदूषण नियंत्रण बोर्ड

CENTRAL POLLUTION CONTROL BOARD

पर्यावरण, वन एवं जलवायु परिवर्तन मंत्रालय भारत सरकार
MINISTRY OF ENVIRONMENT, FORESTS AND CLIMATE CHANGE GOVT. OF INDIA

B-29016/04/06/IPC-1/

4303' SPEED POST

July 17, 2019

M/s. Anphar Laboratories Pvt. Ltd.,
Industrial Extension Area Phase III,
Gangyal, Jammu-180010,
Jammu & Kashmir

Sub.: Directions under Section 5 of the Environment (Protection) Act, 1986- Show cause Notice

WHEREAS, the Pharmaceutical industries are identified as one of the 17 categories of highly polluting industries which have been discharging environmental pollutants directly or indirectly into the ambient air and water, having potential threat to cause adverse effect on the water and air quality; and

WHEREAS, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act, 1986 and the rules framed thereunder; and

WHEREAS, there is need to inculcate habit of self monitoring within the industries for complying with the prescribed standards and this can be achieved by the methods like installing online effluent and emission monitoring devices; and

WHEREAS, pharmaceutical unit M/s. Anphar Laboratories Pvt. Ltd., Jammu (herein after referred to as the Unit) has installed Online Continuous Effluent Monitoring System (OCEMS) and provided connectivity to CPCB server; and

WHEREAS, the Unit was randomly selected for inspection based on the SMS alerts generated during April - May 2019 from the OCEMS installed at the Unit, and

WHEREAS, the Unit was inspected by a team of official(s) from the CPCB Regional Directorate, Lucknow during June 07-08, 2019 to assess the adequacy of the existing pollution control measures and observed the following short comings ;

1. The analysis results of effluent sample from ETP outlet indicate that the treated effluent is exceeding the prescribed limits w.r.t. parameter COD (398 mg/l > 250 mg/l).
2. The analysis results for the effluent samples collected from ETP indicates BOD reduction of 99.85 % and COD reduction of 99.72 % which is not possible considering the treatment system provided by the Unit and unstabilized condition of aeration tank.
3. The electromagnetic flowmeter at the ETP outlet was found non-operational and any flow meter has not been provided at the ETP inlet.
4. The values of OCEMS and analysis results of manual sampling & analysis shows huge variation.
5. The Unit does not have valid authorization under the hazardous and other waste rules 2016.
6. It was observed from the CPCB IT division report dated July 01, 2019 that the Unit has provided OCEMS connectivity for parameters pH, BOD, COD, TSS however the flow meter connectivity has not been provided.

WHEREAS, the Ministry of Environment & Forests, Government of India, vide Notifications No. S. O. 157 (E) of 27.02.1996 and S. O. 730 (E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof.

Page 1 of 2

परिवेश भवन, सूची अर्जुन नगर, दिल्ली-110032

Parivesh Bhawan, East Arjun Nagar, Delhi-110032

दरभाष/Tel : 43102030-22305792 वेबसाइट/Website : www.cpcb.nic.in

NOW, THEREFORE, based on available facts and observations, in exercise of power vested under section 5 of the Environment (Protection) Act, 1986, a notice is hereby served to the Unit (M/s. Anphar Laboratories Pvt. Ltd., Jammu) to show cause as to why all manufacturing & production activities of the Unit should not be closed down as it is not complying on above mentioned short comings.

You are hereby given an opportunity to file your objections (if any) to the above directions within 15 days from the receipt of this notice, failing which action as deemed fit under the provision of Environment (Protection) Act, 1986 will be taken against the Unit.

19-7-14
(S.P. Singh Parihar)

Chairman

Copy to:

1. The Chairman
J&K State Pollution Control Board, Parivesh Bhawan,
Shiekh-ul-Campus, behind Govt. Silk Factory,
Raj Bagh, Srinagar(J&K)
2. The Joint Secretary (CP Division)
Ministry of Environment, Forests and Climate Change
Prithvi Wing, 2nd Floor, Room No. 216, Indira Paryavaran
Bhawan Aliganj, JorBagh Road, New Delhi-110003
4. The Regional Director
Central Pollution Control Board
Ground & First Floor, PICUP Bhawan
Vibhuti Khand, Gomti Nagar
Lucknow - 226 020
- ✓ 5. The Incharge, IT, CPCB
6. The Incharge, IPC-VI, CPCB

(B. Vinod Babu)

Member Secretary