



Speed Post

F. No. PJ-14011(12)/21/2023-WQM-II-HO-CPCB-HO

Date: 13.09.2023

4095

To,

M/s Aadharshree Paper Mills Pvt. Ltd.  
Mangalore – Deoband Road,  
Vill. – Mundet, Roorkee  
Dist. – Haridwar  
Uttarakhand

**DIRECTION UNDER SECTION 5 OF THE ENVIRONMENT (PROTECTION) ACT,  
1986- REG.**

WHEREAS, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act, 1986 and the rules framed there under; and

WHEREAS, the Ministry of Environment & Forests, Govt. of India, vide notification S.O.157(E) of 27.02.1996 has delegated powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board (CPCB), to issue direction to any industry, Municipal Corporation, Municipal Council, Cantonment Board to any local or other Authority for the violation of emission and effluent standards notified under the Environment (Protection) Rules, 1986; and

WHEREAS, it is obligatory on the part of Industries to install effluent treatment plants (ETPs) to comply with the effluent discharge standards as notified under the Environment (Protection) Act, 1986 and the Rules framed thereunder and also to meet the consent conditions granted by State Pollution Control Board (SPCBs)/Pollution Control Committees (PCCs); and

WHEREAS, M/s Aadharshree Paper Mills Pvt. Ltd., Mangalore – Deoband road, Vill. – Mundet, Roorkee, Dist. – Haridwar, Uttarakhand (herein after referred to as "the Unit") is a Pulp & Paper unit involved in the production of Kraft & Poster paper using Waste paper as raw material; and

WHEREAS, the Unit was inspected by CPCB officials under the 'Environmental Surveillance of 17 categories of high pollution potential industries and common facilities, based on OCEMS data programme' on 16.05.2023 and following observations were made:

1. The Industry was found operational during visit.
2. The Unit is engaged in production of MG Kraft Paper and Poster Paper using waste paper as raw material with consented capacity of 23000 MT/year.
3. The Unit has obtained valid Consolidated Consent & Authorization (CCA) with validity up to 31.03.2026.

केन्द्रीय प्रदूषण नियंत्रण बोर्ड  
निर्दिष्ट: Ns/10/9  
दिनांक: 15/9/2023  
दूरभाष: Tel: 43102030, 22305792, वेबसाइट/Website : www.cpcb.nic.in

परिवेश भवन' पर्वी अर्जुन नगर, दिल्ली-110032

Parivesh Bhawan, East Arjun Nagar, Delhi-110032

4. The Unit has one borewell to meet the freshwater requirement for industrial and domestic purposes. Electromagnetic flow meter is installed at the borewell and logbook for freshwater consumption is maintained by the Unit.
5. The Unit has obtained NOC from CGWA for ground water abstraction which is valid upto 28.09.2025.
6. As per logbook the avg. freshwater consumption for April-2023 was 350 m<sup>3</sup>/day, which is equivalent to 7.0 m<sup>3</sup>/ton of paper production.
7. The Unit has agreement with M/s Suraj Plastic Company (valid upto 31.03.2024) for disposal plastic waste generated from waste paper (Pulper machine).
8. The Unit has installed ETP having two stage biological treatment system upto tertiary level.
9. Analysis results of sample collected from ETP Outlet show pH – 7.78 (against 5.5 – 9.0); BOD – 8.9 mg/l (against 20 mg/l); COD – 31.9 mg/l (against 150 mg/l); TSS – 32.5 mg/l (against 30 mg/l); TDS – 373 mg/l (against 1600 mg/l) and Colour – 15 Hazen (against 150 PCU) which indicates that treated effluent is complying w.r.t. consented discharge norms except trivial violation of TSS norm with 32.5 mg/l as against norm of 30 mg/l.
10. The Unit has installed OCEMS at ETP outlet for pH, TSS, BOD, COD & Flow and provided its connectivity with CPCB server. During visit, OCEMS was found operational.
11. The Unit is utilizing 40- 50% of treated effluent in process and remaining are discharge outside the premises. Unit has installed flow meters at recycling point and inlet & outlet of ETP and maintaining logbook for the same.
12. The Unit has separate energy meter for operation of ETP. Logbook of same is maintained.
13. The Unit has one boiler of capacity 10 TPH using wood chips as fuel. Emission from boiler is emitted through stack of height 30 m. The boiler is equipped wet scrubber as APCD. During inspection, the boiler was shut down due to maintenance.

**AND NOW, THEREFORE**, in view of above observations and in exercise of the powers delegated to the Chairman, CPCB under section 5 of the Environment (Protection) Act, 1986, following directions are hereby issued to M/s Aadharshree Paper Mills Pvt. Ltd., Mangalore – Deoband Road, Vill. – Mundet, Roorkee, Dist. – Haridwar, Uttarakhand:

1. Ensure proper operation and maintenance of ETP to meet out the consented discharge norms.
2. Ensure uninterrupted connectivity & regular transmission of OCEMS data to CPCB/UKPCB server.

M/s Aadharshree Paper Mills Pvt. Ltd., Mangalore–Deoband road, Vill.–Mundet, Roorkee, Dist.– Haridwar, Uttarakhand shall ensure the directions mentioned above at Sr. No. 1 & 2 and submit compliance report within 30 days from the date of issue of the directions. In case of failure, the Board will be constrained to initiate action in accordance with the provisions of the Environment (Protection) Act, 1986.

MA 13/0/23  
(TANMAY KUMAR)  
CHAIRMAN

df

**Copy to:**

1. **Additional Secretary (CP Division)** : For kind information, please.  
Ministry of Environment, Forest & C.C  
Prithvi Block, Indira Paryavaran Bhawan,  
Jorbagh Road, New Delhi – 110 003
2. **Member Secretary** : With request to ensure compliance  
Uttarakhand Pollution Control Board of the Direction  
Gaura Devi Bhawan,  
46 B IT Park Sahasradhara,  
Dehradun, Uttarakhand- 248001
3. **Regional Director** : For kind information and follow-up  
Regional Directorate -Lucknow please.  
PICUP Bhawan, Vibhuti Khand, Gomti  
Nagar, Lucknow-226010
4. **Divisional Head, IT Division, CPCB** : For uploading on CPCB website
5. **Master file/Guard file WQM II, CPCB Delhi** : For record



**(BHARAT KUMAR SHARMA)**  
MEMBER SECRETARY