



केन्द्रीय प्रदूषण नियंत्रण बोर्ड
CENTRAL POLLUTION CONTROL BOARD
पर्यावरण, वन एवं जलवायु परिवर्तन मंत्रालय भारत सरकार
MINISTRY OF ENVIRONMENT FOREST & CLIMATE CHANGE GOVT OF INDIA

EMAIL & SPEED POST

IPC-II/TPP/CP-14/30/2023/ 4654

September 27, 2023

To,

The Plant Head / General Manager,
M/s Indraprastha Power Generation Co. Ltd.
I.P. Gas Turbine Power Station (270 MW),
I.P. Estate, Ring Road, New Delhi – 110 002

Sub: Directions under Section 5 of the Environment (Protection) Act, 1986 to M/s Indraprastha Power Generation Co. Ltd., I.P. Gas Turbine Power Station (270 MW), I.P. Estate, Ring Road, New Delhi - reg.

WHEREAS, Thermal Power Plants are identified as one of the 17 categories of highly polluting industries in the country and have been discharging environmental pollutants directly or indirectly into ambient air and water, having potential to cause adverse impact on air and water quality; and

WHEREAS, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Rules, 1986; and

WHEREAS, for strengthening the monitoring and compliance through self-regulatory mechanism, a direction under section 18(1)(b) of the Water (Prevention & Control of Pollution) Act, 1974 and the Air (Prevention & Control of Pollution) Act, 1981 was issued on February 05, 2014 to all the State Pollution Control Boards (SPCBs) / Pollution Control Committees (PCCs) for installation of Online Continuous Emission & Effluent Monitoring Systems (OCEMS) w.r.t. PM, SO₂, NO_x, pH, TSS, BOD, COD, Flow parameters in 17 categories of highly polluting industries, including Thermal Power Plants; and

WHEREAS, the natural gas-based thermal power plants were required to install OCEMS for emission parameter NO_x, and effluent parameters pH, TSS, and Flow; and

WHEREAS, M/s Indraprastha Power Generation Co. Ltd., I.P. Gas Turbine Power Station, I.P. Estate, New Delhi has been inspected by a team of CPCB RD Chandigarh on 26 July 2023 under the environmental surveillance of 17 categories of high pollution potential industries and common facilities based on OCEMS data, in order to verify the environmental compliance and the status of OCEMS. The salient observations based on the inspection carried out by CPCB inspecting team are as below:

‘परिवेश भवन’ पर्वी अर्जुन नगर, दिल्ली-110032

Parivesh Bhawan, East Arjun Nagar, Delhi-110032

दूरभाष/Tel : 43102030, 22305792, वेबसाइट/Website : www.cpcb.nic.in

M/s Indraprastha Power Generation Co. Ltd., I.P. Gas Turbine Power Station, I.P. Estate, New Delhi shall ensure compliance of the above directions and submit compliance report within 30 days from the date of issue of the directions. In case of failure, the Board will be constrained to initiate action as deemed necessary and appropriate in the circumstances under the Environment (Protection) Act, 1986.

13th 27/9/23
(Tanmay Kumar)
Chairman

hwg

Copy to:

1. The Chairman,
Delhi Pollution Control Committee,
4th and 5th Floor, ISBT Building,
Kashmere Gate, **Delhi – 110 006**
2. The Director (CP Division),
Ministry of Environment, Forest and Climate Change,
Indira Paryavaran Bhawan, Aliganj,
Jor Bagh Road, **New Delhi – 110 003**
3. The Regional Director,
Central Pollution Control Board,
BSNL Telephone Exchange, 2nd Floor,
Sector - 49 C, **Chandigarh - 160 059**
4. The District Magistrate (Central Delhi)
District Magistrate Office,
14, Darya Ganj, **New Delhi – 110 002**
5. The Divisional Head - IT, CPCB

Member Secretary

hwg