

**By Speed Post**

F. No. B-190193/NGRBA(RG)/CPCB/P&P/85/2016-17 29 September, 2017

11598

To

**M/s Vishwanath Paper & Boards Ltd.,  
Haldua Shahu, Jaspur Road  
Kashipur (Udham Singh Nagar)  
Uttarakhand**

**DIRECTION UNDER SECTION 5 OF THE ENVIRONMENT (PROTECTION) ACT, 1986**

**WHEREAS**, the Central Government has notified the standards for discharge of environmental pollutants from various categories of industries under the Environment (Protection) Act, 1986 and the rules framed there under; and

**WHEREAS**, the Ministry of Environment, Forest and Climate Change, Govt. of India, vide notification S.O.157(E) of 27.02.1996 has delegated powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board (CPCB), to issue direction to any industry, Municipal Corporation, Municipal Council, Cantonment Board to any local or other Authority for the violation of emission and effluent standards notified under the Environment (Protection) Rules, 1986 and other standards and norms; and

**WHEREAS**, M/s Vishwanath Paper & Boards Ltd., Haldua Shahu, Jaspur Road, Kashipur (Udham Singh Nagar), Uttarakhand (hereinafter referred as 'the Unit') is engaged in the production of Kraft paper using waste paper as raw material; and

**WHEREAS**, Uttarakhand Environment Protection and Pollution Control Board (UEPPCB) issued direction under section 33 (A) of the Water Act, 1974 to the Unit on 13.03.2015 for implementation of the 'Charter for water recycling & pollution prevention in pulp & paper industries' (herein after referred to as 'the charter');

**WHEREAS**, the unit was inspected by the officials of CPCB on December 27, 2016 and CPCB issued show cause notice dated March 07, 2017 to the unit under section 5 of E (P) Act, 1986; and

**WHEREAS**, the unit reply vide letter dated 17.04.2017 was examined and following observations are made:

1. ETP is upgraded up to tertiary level as per the charter.
2. OCEMS is installed and connected with CPCB server.
3. As per the CPPRI report under quarterly assessment the treated effluent parameters are within norms.

**AND WHEREAS**, The unit was inspected by the officials of CPCB on dated 11.07.2017 for compliance verification and made following observations:

4. The Unit & ETP were operational on the day of inspection.
5. The OCEMS is installed and connected with CPCB server.
6. The freshwater requirement is met by two bore wells. The consumption of fresh water is 7.03 M<sup>3</sup>/MT of finished product. The flow meter is installed at recycling point.

Cont.....2/-

7. The ETP consists of Equalization tank, Primary clarifier, Aeration Tank, Secondary Clarifier, Multimedia filter, Sludge press bed.
8. The unit has valid consent under Water & Air Acts till 31.3.2018 and hazardous waste authorization up to 31.03.2018 for production of 5500 MT/ month of craft Paper.
9. The treated effluent analysis report of ETP outlet of the unit showed compliance with BOD-29 mg/l (as against norms of 30 mg/l); TSS 37 mg/l (as against norms of 50 mg/l); COD- 92 mg/l (as against norms of 250 mg/l) pH- 7.33 (as against norms of 6.5-8.5)

**It is evident from the above observations that the Unit is complying with the effluent discharge norms stipulated under the Environment (Protection) Act, 1986.**


**AND NOW, THEREFORE,** in view of the above observations and in exercise of the powers, delegated to the Chairman, CPCB under section 5 of the Environment (Protection) Act, 1986, the show cause notice dated 07.03.2017 issued to the unit **M/s Vishwanath Paper & Boards Ltd., Haldua Shahu, Jaspur Road Kashipur (U.S.Nagar), Uttarakhand** is hereby revoked with following directions to comply:

1. The unit shall provide continuous data for OCEMS on CPCB server.
2. The unit shall operate ETP so as to meet the prescribed norms for effluent discharge.

**(S.P. SINGH PARIHAR)**  
**CHAIRMAN**

**Copy to:**

1. **The Member Secretary** : [For kind information]  
Uttarakhand Environment Protection & Pollution Control Board  
29/20 Nemi Road Dehradun  
Uttarakhand-248001
2. **The Incharge, Zonal Office** : [For kind information]  
Central Pollution Control Board,  
PICUP Bhawan, Ground Floor  
Vibhuti Khand, Gomati Nagar,  
Lucknow-226010
3. **The Advisor (CP Division)** : [For kind information]  
Ministry of Environment, Forests & Climate Change,  
Indra Paryavaran Bhavan,  
Jor Bagh Road, New Delhi - 110 003
4. **The Incharge, IT Division, CPCB** : [For uploading on CPCBs website]
5. **Master copy WQM-II, CPCB**

  
**(A. SUDHAKAR)**  
**MEMBER SECRETARY**