

**SPEED POST**

F. No. B-751 (593)/ Textile/WQM-II/CPCB/2017-18 October 24, 2017

12652

To  
Mamb Woollens Pvt Ltd.,  
Jamunipur,  
Bhadohi (U.P) – 221401

**Show cause under Section 5 of the Environment (Protection) Act, 1986 –reg.**

**WHEREAS**, the Textile dyeing and bleaching industries are identified as one of the Grossly Polluting industries (GPIs) which have been discharging environmental pollutants directly or indirectly into the ambient air and water, having potential threat to cause adverse effect on the water and air quality; and

**WHEREAS**, there is need to inculcate habit of self-monitoring within the industries for complying with the prescribed standards and this can be achieved by the methods like installing online effluent & emission monitoring devices; and

**WHEREAS**, the Ministry of Environment & Forests, Government of India, vide Notifications No.S.O.157(E) of 27.02.1996 and S.O.730(E) dated 10.07.2002, has delegated the powers vested under Section 5 of the Environment (Protection) Act, 1986 (29 of 1986) to the Chairman, Central Pollution Control Board, to issue directions to any industry or any local body or any other authority for violations of the standards and rules notified under the Environment (Protection) Rules, 1986 and amendment thereof; and

**WHEREAS**, CBCB issued revoke direction dated 19.07.2017, under Section 5 of the Environment (Protection) Act, 1986; to the M/s Mamb Woollens Pvt Ltd., Jamunipur, Bhadohi-221401, U. P. (hereafter referred as 'the Unit'), to resume the manufacturing operations and inform to CPCB and to ensure all time compliance of the standards of treated effluent; and

**WHEREAS**, inspection of the unit was conducted on 25.08.2017 by a team of CPCB and following observations made:


1. The unit was found operational on the day of inspection and the unit resumed their manufacturing and processing since 27.07.2017.
2. The unit does not have installed flow meter at the bore well and no logbook is maintained for fresh water withdrawal/ consumption.
3. The unit does not have installed separate energy meter for ETP and no record is maintained for quality of treated effluent as well as sludge disposal.
4. According to treated effluent sample analysis report which was collected from ETP outlet, concentration of BOD found exceeding the stipulated standards, with BOD-31.7 mg/l (norm 30 mg/l).

It evident that the unit is discharging partially treated effluent posing potential threat to river water pollution.

*Contd.*

**NOW, THEREFORE**, in view of the above and in exercise of the powers delegated to the Chairman, Central Pollution Control Board under section 5 of the Environment (Protection) Act, 1986, notice is hereby served to the M/s Mamb Woollens Pvt Ltd., Jamunipur, Bhadohi-221401, U. P to show cause, why the unit should not be closed till all necessary measure are taken by the unit to comply with the prescribed norms.

You are hereby given an opportunity to file your objections (if any) to the above proposed directions within 15 days from the receipt of this notice, failing which appropriate action will be taken against the Unit, without giving any further notice, in accordance with provisions of the Environment (Protection) Act, 1986.

  
(S P SINGH PARIHAR)  
CHAIRMAN

Copy to:

- |     |   |  |
|-----|---|--|
| 1   | Member Secretary<br>Uttar Pradesh Pollution Control Board,<br>Building No. TC-12V, Vibhuti Khand,<br>Gomti Nagar, Lucknow – 226 010                           | With a request to ensure<br>compliance of the<br>directions. |
| 2   | Advisor (CP Division)<br>Ministry of Environment, Forest & Climate Change<br>Prithvi Block, Indira Paryavaran Bhawan,<br>Jorbagh Road,<br>New Delhi – 110 003 | For kind information pls.                                    |
| 3   | Regional Directorate (North),<br>Central Pollution Control Board,<br>PICUP Bhawan, Ground Floor,<br>Vibhuti Khand, Gomti Nagar,<br>Lucknow – 226 010.         | For information.   |
| 4   | In-charge, IPC-III Div., CPCB Delhi   | For information.   |
| ✓ 5 | In-charge, IT Division, CPCB  | For information.   |
| 6   | In-charge, WQM-II Div., CPCB Delhi  | For information.   |

  
(A SUDHAKAR)  
MEMBER SECRETARY