

Specific Checklist, specifying the locations/Places where online effluent/emission monitoring systems/cameras/flow meters that are to be installed in Thermal Power Plants

1. Thermal Power Plants		
Emissions		
Sl. No.	Parameters to be monitored	Location
1	PM	Outlet of ESP*/ Stack (* avoiding turbulence area)
2	SO ₂	Outlet of FGD/Stack
3	NO _x	Outlet of SCR/ Stack
Effluent		
Sl. No.	Parameters to be monitored	Location
1	pH	Outlet of Common Monitoring Basin/ETP Outlet
2	Temperature	Outlet of condenser or at pre-cooling channel before meeting the river or any other water body
3	TSS	Outlet of Common Monitoring Basin/ETP Outlet Outlet of ash pond in case ,AWRS is not installed